

**दिसंबर'24 माह के लिए ओसीसी द्वारा अनुमोदित शटडाउन
OCC Approved Shutdowns for the month of December'24**

क्रम संख्या/ Sl. No.	ओसीसी संख्या/ OCC Number	अनुरोधकर्ता एजेंसी का नाम/ Name of Requesting Agency	तत्व का नाम/ Element Name	धारक/ Owner	दैनिक/निरंतर Daily/ Continuous	कारण/ Reason	आरएलडीसी द्वारा अनुमोदित आरंभ तिथि/ RLDC Approved Start Date	आरएलडीसी स्वीकृत प्रारंभ समय/ RLDC Approved Start Time	आरएलडीसी द्वारा अनुमोदित अंतिम तिथि/ RLDC Approved End Date	आरएलडीसी द्वारा अनुमोदित समाप्ति समय/ RLDC Approved End Time	डी-3 पुष्टिकरण तिथि और समय/ D-3 Confirmation Date and Time	आरएलडीसी संसाधित समय/ RLDC Processed Time	शटडाउन समन्वय प्रक्रिया समय/ Shutdown Co-ordination Process Time
1	OCC_220	AEGCL	220KV-SAMAGURI-SONAPUR-1	AEGCL	D	Corridor cleaning	31/Dec/2024	09:00	31/Dec/2024	16:00	28/Dec/2024 10:19	30/Dec/2024 11:20	49 Hours 1 Minutes
2	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	30/Dec/2024	07:00	30/Dec/2024	17:00	27/Dec/2024 09:36	29/Dec/2024 11:26	49 Hours 26 Minutes
3	OCC_220	AEGCL	220KV-JAWAHARNAGAR-SAMAGURI-1	AEGCL	D	Corridor cleaning	30/Dec/2024	09:00	30/Dec/2024	16:00	27/Dec/2024 10:51	29/Dec/2024 11:26	48 Hours 35 Minutes
4	OCC_220	POWERGRID	400KV-MISA-MARIANI (PG)-2	POWERGRID	D	For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations	30/Dec/2024	09:00	30/Dec/2024	16:00	27/Dec/2024 09:36	29/Dec/2024 11:26	49 Hours 26 Minutes
5	OCC_220	POWERGRID	SILCHAR - 400KV B/R 3	POWERGRID	D	AMP works.	27/Dec/2024	08:00	27/Dec/2024	16:00	24/Dec/2024 08:56	26/Dec/2024 10:37	48 Hours 37 Minutes
6	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	27/Dec/2024	07:00	27/Dec/2024	17:00	24/Dec/2024 08:56	26/Dec/2024 10:37	48 Hours 37 Minutes
7	OCC_220	AEGCL	220KV-AGIA-AZARA-1	AEGCL	D	Corridor cleaning	27/Dec/2024	09:00	27/Dec/2024	16:00	24/Dec/2024 10:49	26/Dec/2024 10:37	47 Hours 48 Minutes
8	OCC_220	POWERGRID	TIE BAY () OF 400KV-BALIPARA-BONGAIGAON-4 AND 400KV-BALIPARA-KAMENG-1 @BALIPARA - 400KV	POWERGRID	D	AMP works	27/Dec/2024	08:00	27/Dec/2024	16:00	24/Dec/2024 08:56	26/Dec/2024 10:37	48 Hours 37 Minutes
9	OCC_220	POWERGRID	400KV-MISA-MARIANI (PG)-2	POWERGRID	D	For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations	27/Dec/2024	09:00	27/Dec/2024	16:00	24/Dec/2024 08:56	26/Dec/2024 10:37	48 Hours 37 Minutes
10	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	26/Dec/2024	07:00	26/Dec/2024	17:00	23/Dec/2024 09:08	25/Dec/2024 11:20	49 Hours 20 Minutes
11	OCC_220	AEGCL	220KV-AGIA-BOKO-1	AEGCL	D	Corridor cleaning	26/Dec/2024	09:00	26/Dec/2024	16:00	23/Dec/2024 10:09	25/Dec/2024 11:20	49 Hours 11 Minutes
12	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	25/Dec/2024	07:00	25/Dec/2024	17:00	22/Dec/2024 09:30	24/Dec/2024 10:07	48 Hours 7 Minutes
13	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	24/Dec/2024	07:00	24/Dec/2024	17:00	21/Dec/2024 08:39	23/Dec/2024 09:21	47 Hours 21 Minutes
14	OCC_220	AEGCL	220KV-TINSUKIA-NRPP-1	ASSAM	D	Corridor cleaning	24/Dec/2024	09:00	24/Dec/2024	16:00	21/Dec/2024 11:42	23/Dec/2024 09:21	45 Hours 39 Minutes

सक्षम
सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी
चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

15	OCC_220	POWERGRID	400KV-MISA-MARIANI (PG)-2	POWERGRID	D	For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations	24/Dec/2024	09:00	24/Dec/2024	16:00	21/Dec/2024 08:39	23/Dec/2024 09:21	47 Hours 21 Minutes
16	OCC_220	POWERGRID	BONGAIGAON - 400KV B/R 4	POWERGRID	D	AMP works	23/Dec/2024	09:00	23/Dec/2024	16:00	20/Dec/2024 11:38	22/Dec/2024 09:44	46 Hours 6 Minutes
17	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	23/Dec/2024	07:00	23/Dec/2024	17:00	20/Dec/2024 11:38	22/Dec/2024 09:44	46 Hours 6 Minutes
18	OCC_220	POWERGRID	25 MVAR TERTIARY REACTOR 3 BAY AT BALIPARA	POWERGRID	D	AMP works	23/Dec/2024	08:00	23/Dec/2024	16:00	20/Dec/2024 11:38	22/Dec/2024 09:44	46 Hours 6 Minutes
19	OCC_220	POWERGRID	400KV-MISA-MARIANI (PG)-2	POWERGRID	D	For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations	23/Dec/2024	09:00	23/Dec/2024	16:00	20/Dec/2024 11:38	22/Dec/2024 09:44	46 Hours 6 Minutes
20	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	22/Dec/2024	07:00	22/Dec/2024	17:00	19/Dec/2024 10:15	21/Dec/2024 11:05	48 Hours 50 Minutes
21	OCC_220	POWERGRID	400KV-MISA-MARIANI (PG)-2	POWERGRID	D	For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations	22/Dec/2024	09:00	22/Dec/2024	16:00	19/Dec/2024 14:12	21/Dec/2024 11:05	44 Hours 53 Minutes
22	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	21/Dec/2024	07:00	21/Dec/2024	17:00	18/Dec/2024 08:27	20/Dec/2024 10:13	48 Hours 13 Minutes
23	OCC_220	POWERGRID	MAIN BAY (2) OF 400KV/132KV BISWANATH CHARIALI-ICT-2 @BISWANATH CHARIALI - 132KV	POWERGRID	D	AMP of bay equipment	21/Dec/2024	09:00	21/Dec/2024	16:00	18/Dec/2024 08:27	20/Dec/2024 10:13	48 Hours 13 Minutes
24	OCC_220	AEGCL	220KV-BALIPARA-SONABIL-2	AEGCL, POWERGRID	D	Corridor cleaning, Bay & Jumper tightening	21/Dec/2024	09:30	21/Dec/2024	15:00	18/Dec/2024 11:37	20/Dec/2024 10:13	46 Hours 36 Minutes
25	OCC_220	AEGCL	132KV-NTPS-TINSUKIA-1	AEGCL	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	21/Dec/2024	09:00	21/Dec/2024	16:00	18/Dec/2024 11:37	20/Dec/2024 10:13	46 Hours 36 Minutes
26	OCC_220	POWERGRID	400KV-MISA-MARIANI (PG)-2	POWERGRID	D	For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations	21/Dec/2024	09:00	21/Dec/2024	16:00	18/Dec/2024 08:27	20/Dec/2024 10:13	48 Hours 13 Minutes
27	OCC_220	POWERGRID	132KV-BADARPUR-KOLASIB-1	POWERGRID	D	For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations	21/Dec/2024	08:00	21/Dec/2024	16:00	18/Dec/2024 08:27	20/Dec/2024 10:13	48 Hours 13 Minutes

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशू

चित्रांशू घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

28	OCC 220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	19/Dec/2024	07:00	19/Dec/2024	17:00	16/Dec/2024 09:09	19/Dec/2024 10:39	48 Hours 39 Minutes
29	OCC 220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	20/Dec/2024	07:00	20/Dec/2024	17:00	17/Dec/2024 08:53	19/Dec/2024 10:02	48 Hours 2 Minutes
30	OCC 220	POWERGRID	MAIN BAY (2) OF 400KV/132KV BISWANATH CHARIALI-ICT-1 @BISWANATH CHARIALI - 132KV	POWERGRID	D	AMP of bay equipment	20/Dec/2024	09:00	20/Dec/2024	16:00	17/Dec/2024 08:53	19/Dec/2024 10:02	48 Hours 2 Minutes
31	OCC 220	AEGCL	220KV-BALIPARA-SONABIL-1	AEGCL,POWERGRID	D	Corridor cleaning, Bay & Jumper tightening	20/Dec/2024	09:30	20/Dec/2024	15:00	17/Dec/2024 09:58	19/Dec/2024 10:02	48 Hours 2 Minutes
32	OCC 220	AEGCL	220KV-BTPS-RANGIA-2	AEGCL	D	PREVENTIVE MAINTENANCE	20/Dec/2024	08:00	20/Dec/2024	16:00	17/Dec/2024 09:58	19/Dec/2024 10:02	48 Hours 2 Minutes
33	OCC 220	AEGCL	220KV-NTPS-AMGURI-1	AEGCL	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	20/Dec/2024	08:00	20/Dec/2024	16:00	17/Dec/2024 09:58	19/Dec/2024 10:02	48 Hours 2 Minutes
34	OCC 220	AEGCL	132KV-GOHPUR-NALKATA-2	POWERGRID	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	20/Dec/2024	07:00	20/Dec/2024	14:00	17/Dec/2024 09:58	19/Dec/2024 10:02	48 Hours 2 Minutes
35	OCC 220	AEGCL	132KV-SARUPATHAR-BOKAJAN-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	20/Dec/2024	09:00	20/Dec/2024	16:00	17/Dec/2024 09:58	19/Dec/2024 10:02	48 Hours 2 Minutes
36	OCC 220	POWERGRID	400KV-MISA-MARIANI (PG)-2	POWERGRID	D	For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations	20/Dec/2024	09:00	20/Dec/2024	16:00	17/Dec/2024 08:53	19/Dec/2024 10:02	48 Hours 2 Minutes
37	OCC 220	POWERGRID	400KV-BALIPARA-KAMENG-2	POWERGRID	D	ENABLING OF THE DEF AUTO-RECLOSE IN MAIN-1 AND MAIN-2 DISTANCE PROTECTION RELAY	20/Dec/2024	08:00	20/Dec/2024	16:00	17/Dec/2024 08:53	19/Dec/2024 10:02	48 Hours 2 Minutes
38	OCC 220	AEGCL	132KV-DHARMANAGAR (MISSION TILLA)-DULLAVCHERRA-1	AEGCL,TS ECL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	19/Dec/2024	09:00	19/Dec/2024	16:00	16/Dec/2024 10:12	18/Dec/2024 11:08	48 Hours 56 Minutes
39	OCC 220	AEGCL	132KV-GOHPUR-NALKATA-1	POWERGRID	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	19/Dec/2024	07:00	19/Dec/2024	14:00	16/Dec/2024 10:12	18/Dec/2024 11:08	48 Hours 56 Minutes
40	OCC 220	AEGCL	220KV-AGIA-BTPS-2	AEGCL	D	Corridor cleaning	19/Dec/2024	09:00	19/Dec/2024	16:00	16/Dec/2024 10:12	18/Dec/2024 11:08	48 Hours 56 Minutes
41	OCC 220	POWERGRID	400KV-BALIPARA-KAMENG-1	POWERGRID	D	ENABLING OF THE DEF AUTO-RECLOSE IN MAIN-1 AND MAIN-2 DISTANCE PROTECTION RELAY	19/Dec/2024	08:00	19/Dec/2024	16:00	16/Dec/2024 09:09	18/Dec/2024 11:08	49 Hours 8 Minutes
42	OCC 220	MEPTCL	132KV-UMTRU-SARUSAJAI-1	MEPTCL	D	For Lines maintenance works	19/Dec/2024	08:00	19/Dec/2024	16:00	16/Dec/2024 05:43	18/Dec/2024 11:08	49 Hours 8 Minutes
43	OCC 220	MEPTCL	132KV-UMTRU-SARUSAJAI-2	MEPTCL	D	For Lines maintenance works	19/Dec/2024	08:00	19/Dec/2024	16:00	16/Dec/2024 05:43	18/Dec/2024 11:08	49 Hours 8 Minutes
44	OCC 220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	18/Dec/2024	07:00	18/Dec/2024	17:00	15/Dec/2024 09:44	17/Dec/2024 10:54	48 Hours 54 Minutes
45	OCC 220	AEGCL	220KV-SONAPUR-SARUSAJAI-1	AEGCL	D	Corridor cleaning	18/Dec/2024	10:00	18/Dec/2024	12:30	15/Dec/2024 10:49	17/Dec/2024 10:54	48 Hours 5 Minutes

सक्षम

सक्षम रिठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitrangshi Ghangrekar (Dy. General Manager)

46	OCC_220	AEGCL	132KV-DHARMANAGAR (MISSION TILLA)-DULLAVCHERRA-1	AEGCL,TS ECL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	18/Dec/2024	09:00	18/Dec/2024	16:00	15/Dec/2024 10:49	17/Dec/2024 10:54	48 Hours 5 Minutes
47	OCC_220	AEGCL	220KV-BTPS-RANGIA-1	AEGCL	D	PREVENTIVE MAINTENANCE	18/Dec/2024	08:00	18/Dec/2024	16:00	15/Dec/2024 10:49	17/Dec/2024 10:54	48 Hours 5 Minutes
48	OCC_220	AEGCL	132KV-BOKAJAN-DIMAPUR(PG)	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING	18/Dec/2024	09:00	18/Dec/2024	16:00	15/Dec/2024 10:49	17/Dec/2024 10:54	48 Hours 5 Minutes
49	OCC_220	AEGCL	132KV-SARUPATHAR-GOLAGHAT-1	AEGCL	D	Corridor cleaning	16/Dec/2024	09:00	16/Dec/2024	15:00	13/Dec/2024 08:36	15/Dec/2024 09:38	47 Hours 38 Minutes
50	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	17/Dec/2024	07:00	17/Dec/2024	17:00	14/Dec/2024 08:43	16/Dec/2024 10:54	48 Hours 54 Minutes
51	OCC_220	AEGCL	220KV-AZARA-SARUSAJAI-2	AEGCL	D	ROUTINE EQUIPMENT TESTING	17/Dec/2024	08:00	17/Dec/2024	16:00	14/Dec/2024 10:19	16/Dec/2024 10:54	48 Hours 35 Minutes
52	OCC_220	AEGCL	220KV-MARIANI (AS)-SAMAGURI-2	AEGCL	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	17/Dec/2024	08:00	17/Dec/2024	16:00	14/Dec/2024 10:19	16/Dec/2024 10:54	48 Hours 35 Minutes
53	OCC_220	AEGCL	220KV-AGIA-BTPS-1	AEGCL	D	Corridor cleaning	17/Dec/2024	09:00	17/Dec/2024	16:00	14/Dec/2024 10:19	16/Dec/2024 10:54	48 Hours 35 Minutes
54	OCC_220	POWERGRID	400 KV BALIPARA 1 BAY AT HVDC BNC	POWERGRID	D	AMP of bay equipment	16/Dec/2024	09:00	16/Dec/2024	16:00	13/Dec/2024 08:36	15/Dec/2024 09:38	47 Hours 38 Minutes
55	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	16/Dec/2024	07:00	16/Dec/2024	17:00	13/Dec/2024 08:36	15/Dec/2024 09:38	47 Hours 38 Minutes
56	OCC_220	POWERGRID	BONGAIGAON - 400KV B/R 5	POWERGRID	D	AMP works	16/Dec/2024	09:00	16/Dec/2024	16:00	13/Dec/2024 12:22	15/Dec/2024 09:38	45 Hours 16 Minutes
57	OCC_220	AEGCL	132KV-SRIKONA-PAILAPPOL-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	16/Dec/2024	09:00	16/Dec/2024	16:00	13/Dec/2024 10:30	15/Dec/2024 09:38	47 Hours 8 Minutes
58	OCC_220	POWERGRID	MAIN BAY (203) OF 220KV-BALIPARA-SONABIL-1 @BALIPARA - 220KV	POWERGRID	D	AMP works	16/Dec/2024	08:00	16/Dec/2024	16:00	13/Dec/2024 09:24	15/Dec/2024 09:38	47 Hours 38 Minutes
59	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	15/Dec/2024	07:00	15/Dec/2024	17:00	12/Dec/2024 09:09	14/Dec/2024 10:21	48 Hours 21 Minutes
60	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	14/Dec/2024	07:00	14/Dec/2024	17:00	11/Dec/2024 08:30	13/Dec/2024 10:42	48 Hours 42 Minutes
61	OCC_220	AEGCL	220KV-BONGAIGAON-BTPS-2	ASSAM	D	PERIODIC MAINTENANCE	14/Dec/2024	09:00	14/Dec/2024	14:00	11/Dec/2024 11:08	13/Dec/2024 10:42	47 Hours 34 Minutes
62	OCC_220	POWERGRID	220KV-SALAKATI-BTPS-2	POWERGRID	D	FOR AMP WORKS	14/Dec/2024	09:00	14/Dec/2024	17:00	11/Dec/2024 08:30	13/Dec/2024 10:42	48 Hours 42 Minutes
63	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	13/Dec/2024	07:00	13/Dec/2024	17:00	10/Dec/2024 10:15	13/Dec/2024 09:58	47 Hours 58 Minutes
64	OCC_220	AEGCL	132KV-HAILAKANDI-DULLAVCHERRA-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	13/Dec/2024	09:00	13/Dec/2024	16:00	10/Dec/2024 11:05	13/Dec/2024 09:58	47 Hours 58 Minutes
65	OCC_220	AEGCL	132KV-JIRIBAM(PG)-PAILAPPOL-1	MSPCL,AE GCL	D	Corridor cleaning	13/Dec/2024	09:00	13/Dec/2024	16:00	10/Dec/2024 11:05	13/Dec/2024 09:58	47 Hours 58 Minutes
66	OCC_220	AEGCL	220KV-AGIA-AZARA-1	AEGCL	D	Corridor cleaning	13/Dec/2024	09:00	13/Dec/2024	16:00	10/Dec/2024 11:05	13/Dec/2024 09:58	47 Hours 58 Minutes

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

67	OCC_220	AEGCL	220KV-BTPS-RANGIA-2	AEGCL	D	PREVENTIVE MAINTENANCE	13/Dec/2024	08:00	13/Dec/2024	16:00	10/Dec/2024 11:05	13/Dec/2024 09:58	47 Hours 58 Minutes
68	OCC_220	AEGCL	220KV-NTPS-AMGURI-1	AEGCL	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	13/Dec/2024	08:00	13/Dec/2024	16:00	10/Dec/2024 11:05	13/Dec/2024 09:58	47 Hours 58 Minutes
69	OCC_220	POWERGRID	400 KV, 50 MVAR BUS REACTOR 2 BAY AT BONGAIGAON	POWERGRID	D	AMP of bay equipment	13/Dec/2024	09:00	13/Dec/2024	16:00	10/Dec/2024 10:15	13/Dec/2024 09:58	47 Hours 58 Minutes
70	OCC_220	POWERGRID	TIE BAY () OF BALIPARA - 400KV B/R 3 AND FUTURE @BALIPARA - 400KV	POWERGRID	D	AMP works	13/Dec/2024	08:00	13/Dec/2024	16:00	10/Dec/2024 10:15	13/Dec/2024 09:58	47 Hours 58 Minutes
71	OCC_220	POWERGRID	220KV-SALAKATI-BTPS-1	POWERGRID	D	FOR AMP WORKS	13/Dec/2024	09:00	13/Dec/2024	17:00	10/Dec/2024 10:15	13/Dec/2024 09:58	47 Hours 58 Minutes
72	OCC_220	MEPTCL	220KV-MAWNGAP-BYRNIHAT (KILLING)-1	MEGHALAYA	D	For Line maintenance works and Jungle Clearance	13/Dec/2024	08:00	13/Dec/2024	16:00	10/Dec/2024 08:02	13/Dec/2024 09:58	47 Hours 58 Minutes
73	OCC_220	MEPTCL	220KV-MAWNGAP-BYRNIHAT (KILLING)-2	MEGHALAYA	D	For Line maintenance works and Jungle Clearance	13/Dec/2024	08:00	13/Dec/2024	16:00	10/Dec/2024 08:02	13/Dec/2024 09:58	47 Hours 58 Minutes
74	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	12/Dec/2024	07:00	12/Dec/2024	17:00	09/Dec/2024 10:05	11/Dec/2024 11:05	49 Hours 0 Minutes
75	OCC_220	POWERGRID	MAIN BAY () OF 400KV-BISWANATH CHARIALI-SUBANSIRI-2 @BISWANATH CHARIALI - 400KV	POWERGRID	D	AMP of bay equipment	12/Dec/2024	09:00	12/Dec/2024	16:00	09/Dec/2024 10:05	11/Dec/2024 11:05	49 Hours 0 Minutes
76	OCC_220	AEGCL	AZARA - 400KV B/R 1	AEGCL	D	ROUTINE EQUIPMENT TESTING	12/Dec/2024	08:00	12/Dec/2024	16:00	09/Dec/2024 10:51	11/Dec/2024 11:05	48 Hours 14 Minutes
77	OCC_220	POWERGRID	220KV/132KV SALAKATI-ICT-3	POWERGRID	D	For AMP testing of bushing, CT Tan delta, IR of LA, PI & DI of ICT etc. 100MVA ICT-III will be under SD.	12/Dec/2024	08:00	12/Dec/2024	16:00	09/Dec/2024 10:05	11/Dec/2024 11:05	49 Hours 0 Minutes
78	OCC_220	MEPTCL	220KV-MAWNGAP-BYRNIHAT (KILLING)-1	MEGHALAYA	D	For Line maintenance works and Jungle Clearance	12/Dec/2024	08:00	12/Dec/2024	16:00	09/Dec/2024 00:57	11/Dec/2024 11:05	49 Hours 5 Minutes
79	OCC_220	MEPTCL	220KV-MAWNGAP-BYRNIHAT (KILLING)-2	MEGHALAYA	D	For Line maintenance works and Jungle Clearance	12/Dec/2024	08:00	12/Dec/2024	16:00	09/Dec/2024 00:59	11/Dec/2024 11:05	49 Hours 5 Minutes
80	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	11/Dec/2024	07:00	11/Dec/2024	17:00	08/Dec/2024 08:48	10/Dec/2024 11:23	49 Hours 23 Minutes
81	OCC_220	POWERGRID	MAIN BAY (1) OF 400KV/132KV BISWANATH CHARIALI-ICT-1 @BISWANATH CHARIALI - 400KV	POWERGRID	D	AMP of bay equipment	11/Dec/2024	09:00	11/Dec/2024	16:00	08/Dec/2024 08:48	10/Dec/2024 11:23	49 Hours 23 Minutes
82	OCC_220	POWERGRID	220KV MAIN BAY OF 220KV/132KV SALAKATI-ICT-3 @SALAKATI - 220KV	POWERGRID	D	For DCRM & Timing Measurement of CB. 220kV side (HV) of 100MVA ICT-III will be charged through 220KV TBC bay. There will no outage of ICT-III.	11/Dec/2024	08:00	11/Dec/2024	16:00	08/Dec/2024 08:48	10/Dec/2024 11:23	49 Hours 23 Minutes
83	OCC_220	AEGCL	220KV-SAMAGURI-SONAPUR-1	AEGCL	D	Corridor cleaning	11/Dec/2024	09:00	11/Dec/2024	16:00	08/Dec/2024 11:22	10/Dec/2024 11:23	48 Hours 1 Minutes
84	OCC_220	AEGCL	132KV-HAILAKANDI-PANCHGRAM (NEW)-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	11/Dec/2024	09:00	11/Dec/2024	16:00	08/Dec/2024 11:11	10/Dec/2024 11:23	48 Hours 12 Minutes
85	OCC_220	AEGCL	220KV-AGIA-BOKO-1	AEGCL	D	Corridor cleaning	11/Dec/2024	09:00	11/Dec/2024	16:00	08/Dec/2024 11:37	10/Dec/2024 11:23	47 Hours 46 Minutes
86	OCC_220	AEGCL	220KV-BTPS-RANGIA-1	AEGCL	D	PREVENTIVE MAINTENANCE	11/Dec/2024	08:00	11/Dec/2024	16:00	08/Dec/2024 10:58	10/Dec/2024 11:23	48 Hours 25 Minutes

सहायक

सक्षम रिठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशु

चित्रांशु घांगरेकर (उप महाप्रबंधक)
Chitranshu Ghangrekar (Dy. General Manager)

87	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-1	AEGCL	D	Corridor cleaning	11/Dec/2024	09:30	11/Dec/2024	15:00	08/Dec/2024 11:01	10/Dec/2024 11:23	48 Hours 22 Minutes
88	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-2	AEGCL	D	Corridor cleaning	11/Dec/2024	09:30	11/Dec/2024	15:00	08/Dec/2024 11:01	10/Dec/2024 11:23	48 Hours 22 Minutes
89	OCC_220	POWERGRID	400 KV BALIPARA II & 50 MVAR BUS REACTOR IIAT BONGAIGAON	POWERGRID	D	AMP of bay equipment	11/Dec/2024	09:00	11/Dec/2024	16:00	08/Dec/2024 08:48	10/Dec/2024 11:23	49 Hours 23 Minutes
90	OCC_220	POWERGRID	MAIN BAY (401) OF 400KV/220KV BALIPARA-ICT-2 AND @BALIPARA - 400KV	POWERGRID	D	AMP works	11/Dec/2024	08:00	11/Dec/2024	16:00	08/Dec/2024 08:48	10/Dec/2024 11:23	49 Hours 23 Minutes
91	OCC_220	POWERGRID	220KV-SALAKATI-BTPS-1	POWERGRID	D	FOR AMP WORKS	11/Dec/2024	10:00	11/Dec/2024	17:00	08/Dec/2024 08:48	10/Dec/2024 11:23	49 Hours 23 Minutes
92	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	10/Dec/2024	07:00	10/Dec/2024	17:00	07/Dec/2024 09:46	09/Dec/2024 11:04	49 Hours 4 Minutes
93	OCC_220	POWERGRID	BUS COUPLER BAY () OF BISWANATH CHARIALI - 132KV - BUS 1 AND BISWANATH CHARIALI - 132KV - BUS 2 @BISWANATH CHARIALI - 132KV	POWERGRID	D	AMP of bay equipment	10/Dec/2024	09:00	10/Dec/2024	16:00	07/Dec/2024 09:46	09/Dec/2024 11:04	49 Hours 4 Minutes
94	OCC_220	POWERGRID	132KV MAIN BAY OF 220KV/132KV SALAKATI-ICT-3 @SALAKATI - 132KV	POWERGRID	D	For DCRM & Timing Measurement of CB. 132kv side (LV) of 100MVA ICT-III will charged through 132kv TBC bay. There will no outage of ICT-III.	10/Dec/2024	08:00	10/Dec/2024	16:00	07/Dec/2024 09:46	09/Dec/2024 11:04	49 Hours 4 Minutes
95	OCC_220	AEGCL	132KV-HAILAKANDI-PANCHGRAM (NEW)-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	10/Dec/2024	09:00	10/Dec/2024	16:00	07/Dec/2024 11:42	09/Dec/2024 11:04	47 Hours 22 Minutes
96	OCC_220	AEGCL	400KV/220KV AZARA-ICT-2	AEGCL	D	ROUTINE EQUIPMENT TESTING	10/Dec/2024	08:00	10/Dec/2024	16:00	07/Dec/2024 11:42	09/Dec/2024 11:04	47 Hours 22 Minutes
97	OCC_220	AEGCL	220KV-MARIANI (AS)-SAMAGURI-2	AEGCL	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	10/Dec/2024	08:00	10/Dec/2024	16:00	07/Dec/2024 11:42	09/Dec/2024 11:04	47 Hours 22 Minutes
98	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-1	AEGCL	D	Corridor cleaning	10/Dec/2024	09:30	10/Dec/2024	15:00	07/Dec/2024 11:42	09/Dec/2024 11:04	47 Hours 22 Minutes
99	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-2	AEGCL	D	Corridor cleaning	10/Dec/2024	09:30	10/Dec/2024	15:00	07/Dec/2024 11:42	09/Dec/2024 11:04	47 Hours 22 Minutes
100	OCC_220	POWERGRID	220KV/132KV KOPILI-ICT-2	POWERGRID	D	Warranty test for GIS equipments	10/Dec/2024	08:00	10/Dec/2024	16:00	07/Dec/2024 09:46	09/Dec/2024 11:04	49 Hours 4 Minutes
101	OCC_220	POWERGRID	220KV-BONGAIGAON-SALAKATI-2	POWERGRID	D	FOR AMP WORKS	09/Dec/2024	09:00	09/Dec/2024	17:00	06/Dec/2024 13:07	08/Dec/2024 11:12	46 Hours 5 Minutes
102	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	09/Dec/2024	07:00	09/Dec/2024	17:00	06/Dec/2024 10:31	08/Dec/2024 11:12	48 Hours 41 Minutes
103	OCC_220	POWERGRID	FILTER BANK1 MAIN BAY AT BNC	POWERGRID	D	AMP of bay equipment	09/Dec/2024	09:00	09/Dec/2024	16:00	06/Dec/2024 10:38	08/Dec/2024 11:12	48 Hours 34 Minutes
104	OCC_220	AEGCL	132KV-SRIKONA-PAILAPPOL-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	09/Dec/2024	09:00	09/Dec/2024	16:00	06/Dec/2024 10:38	08/Dec/2024 11:12	48 Hours 34 Minutes
105	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-2	AEGCL	D	Corridor cleaning	09/Dec/2024	09:30	09/Dec/2024	15:00	06/Dec/2024 10:38	08/Dec/2024 11:12	48 Hours 34 Minutes
106	OCC_220	POWERGRID	400 KV BGTPP 2 BAY AT BONGAIGAON	POWERGRID	D	AMP of bay equipment	09/Dec/2024	09:00	09/Dec/2024	16:00	06/Dec/2024 10:07	08/Dec/2024 11:12	49 Hours 5 Minutes

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रंशी

चित्रंशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

107	OCC_220	POWERGRID	400,50 MVAR BUS REACTOR 1 BAY AT BALIPARA	POWERGRID	D	AMP works	09/Dec/2024	08:00	09/Dec/2024	16:00	06/Dec/2024 10:31	08/Dec/2024 11:12	48 Hours 41 Minutes
108	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	08/Dec/2024	07:00	08/Dec/2024	17:00	05/Dec/2024 17:37	07/Dec/2024 07:34	37 Hours 57 Minutes
109	OCC_220	POWERGRID	400KV-BONGAIGAON-BYRNIHAT (KILLING)	MEPTCL,NETC	D	AMP works	07/Dec/2024	09:00	07/Dec/2024	16:00	04/Dec/2024 11:34	06/Dec/2024 11:22	47 Hours 48 Minutes
110	OCC_220	POWERGRID	400KV-BONGAIGAON-BYRNIHAT (KILLING) L/R@ BONGAIGAON - 400KV	POWERGRID	D	AMP works	07/Dec/2024	09:00	07/Dec/2024	16:00	04/Dec/2024 11:34	06/Dec/2024 11:22	47 Hours 48 Minutes
111	OCC_220	AEGCL	132KV-RUPAI-CHAPAKHOWA-1	AEGCL	D	CORRIDOR CLEANING.	07/Dec/2024	09:00	07/Dec/2024	16:00	04/Dec/2024 11:34	06/Dec/2024 11:22	47 Hours 48 Minutes
112	OCC_220	AEGCL	220KV-SAMAGURI-SONABIL-2	AEGCL	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	07/Dec/2024	08:00	07/Dec/2024	16:00	04/Dec/2024 11:34	06/Dec/2024 11:22	47 Hours 48 Minutes
113	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-2	AEGCL	D	Corridor cleaning	07/Dec/2024	09:30	07/Dec/2024	15:00	04/Dec/2024 11:34	06/Dec/2024 11:22	47 Hours 48 Minutes
114	OCC_220	POWERGRID	132KV/33KV ZIRO-ICT-1	POWERGRID	D	AMP of ICT	07/Dec/2024	08:00	07/Dec/2024	16:00	04/Dec/2024 10:45	06/Dec/2024 11:22	48 Hours 37 Minutes
115	OCC_220	MEPTCL	AMPATI - 132KV - BUS 1	MEHGALAYA	D	Preventive Maintenance work	07/Dec/2024	08:00	07/Dec/2024	12:00	04/Dec/2024 09:19	06/Dec/2024 11:22	49 Hours 22 Minutes
116	OCC_220	POWERGRID	400KV-AZARA-BONGAIGAON-1	NETC,AEGCL	D	AMP works	06/Dec/2024	09:00	06/Dec/2024	16:00	03/Dec/2024 12:21	05/Dec/2024 11:37	47 Hours 16 Minutes
117	OCC_220	POWERGRID	400KV-AZARA-BONGAIGAON L/R@ BONGAIGAON - 400KV	POWERGRID	D	AMP works	06/Dec/2024	09:00	06/Dec/2024	16:00	03/Dec/2024 12:21	05/Dec/2024 11:37	47 Hours 16 Minutes
118	OCC_220	POWERGRID	FILTER BANK 3 SUB BANKS BAY AT BNC	POWERGRID	D	AMP of bay equipment	06/Dec/2024	08:00	06/Dec/2024	16:00	03/Dec/2024 12:21	05/Dec/2024 11:37	47 Hours 16 Minutes
119	OCC_220	AEGCL	132KV-TINSUKIA-RUPAI-1	AEGCL	D	CORRIDOR CLEANING.	06/Dec/2024	09:00	06/Dec/2024	16:00	03/Dec/2024 12:21	05/Dec/2024 11:37	47 Hours 16 Minutes
120	OCC_220	AEGCL	220KV-MARIANI (AS)-AMGURI-1	AEGCL	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	06/Dec/2024	08:00	06/Dec/2024	16:00	03/Dec/2024 12:21	05/Dec/2024 11:37	47 Hours 16 Minutes
121	OCC_220	AEGCL	220KV-SAMAGURI-SONABIL-1	AEGCL	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	06/Dec/2024	08:00	06/Dec/2024	16:00	03/Dec/2024 12:21	05/Dec/2024 11:37	47 Hours 16 Minutes
122	OCC_220	AEGCL	132KV-GOHPUR-NALKATA-2	POWERGRID	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	06/Dec/2024	07:00	06/Dec/2024	14:00	03/Dec/2024 12:21	05/Dec/2024 11:37	47 Hours 16 Minutes
123	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-2	AEGCL	D	Corridor cleaning	06/Dec/2024	09:30	06/Dec/2024	15:00	03/Dec/2024 12:21	05/Dec/2024 11:37	47 Hours 16 Minutes
124	OCC_220	POWERGRID	400 KV BALIPARA 4 BAY (WITH 63 MVAR LINE REACTOR) AT BONGAIGAON	POWERGRID	D	AMP of bay equipment	06/Dec/2024	09:00	06/Dec/2024	16:00	03/Dec/2024 09:08	05/Dec/2024 11:37	49 Hours 37 Minutes
125	OCC_220	POWERGRID	220KV/132KV SALAKATI-ICT-2	POWERGRID	D	AMP WORKS	06/Dec/2024	08:00	06/Dec/2024	16:00	03/Dec/2024 09:08	05/Dec/2024 11:37	49 Hours 37 Minutes
126	OCC_220	POWERGRID	400 KV BONGAIGAON 1 MAIN BAY (WITH 63 MVAR LINE REACTOR) (413) AT BALIPARA	POWERGRID	D	AMP works	06/Dec/2024	08:00	06/Dec/2024	16:00	03/Dec/2024 09:08	05/Dec/2024 11:37	49 Hours 37 Minutes
127	OCC_220	POWERGRID	400KV/220KV MARIANI (PG)-ICT-2	POWERGRID	D	AMP of ICT	06/Dec/2024	08:00	06/Dec/2024	16:00	03/Dec/2024 09:08	05/Dec/2024 11:37	49 Hours 37 Minutes

सहायक

सक्षम शेटे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

128	OCC_220	MEPTCL	AMPATI - 132KV - BUS 1	MEHGALAYA	D	Preventive Maintenance work	06/Dec/2024	08:00	06/Dec/2024	12:00	03/Dec/2024 08:37	05/Dec/2024 11:37	49 Hours 37 Minutes
129	OCC_220	MEPTCL	220KV-BYRNIAHAT (KILLING)-MISA-1	MEPTCL	D	For Lines maintenance works	06/Dec/2024	08:00	06/Dec/2024	16:00	03/Dec/2024 08:37	05/Dec/2024 11:37	49 Hours 37 Minutes
130	OCC_220	MEPTCL	220KV-BYRNIAHAT (KILLING)-MISA-2	MEPTCL	D	For Lines maintenance works	06/Dec/2024	08:00	06/Dec/2024	16:00	03/Dec/2024 08:37	05/Dec/2024 11:37	49 Hours 37 Minutes
131	OCC_220	AEGCL	132KV-LUMSNONG-PANCHGRAM (NEW)-1	MEPTCL, AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	20/Dec/2024	09:00	20/Dec/2024	16:00	02/Dec/2024 11:10	04/Dec/2024 11:17	48 Hours 7 Minutes
132	OCC_220	AEGCL	220KV-JAWAHARNAGAR-SAMAGURI-1	AEGCL	D	Corridor cleaning	05/Dec/2024	09:00	05/Dec/2024	16:00	02/Dec/2024 11:10	04/Dec/2024 11:17	48 Hours 7 Minutes
133	OCC_220	AEGCL	BTPS - 220KV - BUS 1	AEGCL	D	Replacement of 220KV Bus dropping conductor and periodic maintenance works	05/Dec/2024	09:00	05/Dec/2024	16:00	02/Dec/2024 11:10	04/Dec/2024 11:17	48 Hours 7 Minutes
134	OCC_220	AEGCL	400KV/220KV BGTTP-ICT-1	NTPC	D	Replacement of 220KV Bus dropping conductor and periodic maintenance works	05/Dec/2024	09:00	05/Dec/2024	16:00	02/Dec/2024 11:10	04/Dec/2024 11:17	48 Hours 7 Minutes
135	OCC_220	AEGCL	132KV-GOHPUR-NALKATA-1	POWERGRID	D	CORRIDOR CLEANING LINE MAINTENANCE WORKS	05/Dec/2024	07:00	05/Dec/2024	14:00	02/Dec/2024 11:10	04/Dec/2024 11:17	48 Hours 7 Minutes
136	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-1	AEGCL	D	Corridor cleaning	05/Dec/2024	09:30	05/Dec/2024	15:00	02/Dec/2024 11:10	04/Dec/2024 11:17	48 Hours 7 Minutes
137	OCC_220	POWERGRID	FILTER BANK 3 SUB BANK4 BAY AT BNC	POWERGRID	D	AMP of bay equipment	05/Dec/2024	09:00	05/Dec/2024	16:00	02/Dec/2024 09:46	04/Dec/2024 11:17	49 Hours 17 Minutes
138	OCC_220	POWERGRID	220 KV, 50 MVA ICT 2 BAY AT SALAKATI	POWERGRID	D	For DCRM & Timing Measurement of CB, 220kV side (HV) of 50MVA ICT-II will charged through 220kV TBC bay. There will no outage of ICT-II.	05/Dec/2024	08:00	05/Dec/2024	16:00	02/Dec/2024 09:46	04/Dec/2024 11:17	49 Hours 17 Minutes
139	OCC_220	POWERGRID	MAIN BAY () OF 400KV/220KV MARIANI (PG)-ICT-2 @MARIANI (PG) - 400KV(409)	POWERGRID	D	AMP of bay equipment	05/Dec/2024	08:00	05/Dec/2024	16:00	02/Dec/2024 09:46	04/Dec/2024 11:17	49 Hours 17 Minutes
140	OCC_220	POWERGRID	220KV/132KV KOPILI-ICT-1	POWERGRID	D	Warranty test for GIS equipments	05/Dec/2024	08:00	05/Dec/2024	16:00	02/Dec/2024 09:46	04/Dec/2024 11:17	49 Hours 17 Minutes
141	OCC_220	POWERGRID	132KV-SILCHAR-BADARPUR-2	POWERGRID	D	For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations	05/Dec/2024	08:00	05/Dec/2024	16:00	02/Dec/2024 09:46	04/Dec/2024 11:17	49 Hours 17 Minutes
142	OCC_220	POWERGRID	132KV-KHLIEHRIAT(ME)-KHLIEHRIAT-1	POWERGRID	D	FOR AMP WORKS	05/Dec/2024	08:00	05/Dec/2024	16:00	02/Dec/2024 09:46	04/Dec/2024 11:17	49 Hours 17 Minutes
143	OCC_220	MEPTCL	KHLIEHRIAT(ME) - 132KV - BUS 1	MEPTCL	D	Maintenance work of all Bus sides of all 132kV line bays.	05/Dec/2024	10:00	05/Dec/2024	16:00	02/Dec/2024 07:01	04/Dec/2024 11:17	49 Hours 17 Minutes
144	OCC_220	POWERGRID	400KV-BALIPARA-BONGAIGAON-1	POWERGRID	D	For OPGW installation work under reliable communication Scheme on long spans in the area of deep valleys/River crossing etc	06/Dec/2024	07:00	06/Dec/2024	17:00	03/Dec/2024 08:37	05/Dec/2024 11:37	49 Hours 37 Minutes
145	OCC_220	AEGCL	132KV-LUMSNONG-PANCHGRAM (NEW)-1	MEPTCL, AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	04/Dec/2024	09:00	04/Dec/2024	16:00	01/Dec/2024 10:45	03/Dec/2024 10:26	47 Hours 41 Minutes
146	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-1	AEGCL	D	Corridor cleaning	04/Dec/2024	09:30	04/Dec/2024	15:00	01/Dec/2024 10:40	03/Dec/2024 10:26	47 Hours 46 Minutes
147	OCC_220	POWERGRID	FILTER BANK 3 SUB BANK3 BAY AT BNC	POWERGRID	D	AMP of bay equipment	04/Dec/2024	09:00	04/Dec/2024	16:00	01/Dec/2024 10:40	03/Dec/2024 10:26	47 Hours 46 Minutes

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

148	OCC_220	POWERGRID	400 KV BALIPARA 3 BAY (WITH 63 MVAR LINE REACTOR) (418) AT BONGAIGAON	POWERGRID	D	AMP of bay equipment	04/Dec/2024	09:00	04/Dec/2024	16:00	01/Dec/2024 08:48	03/Dec/2024 10:26	48 Hours 26 Minutes
149	OCC_220	AEGCL	132KV-GOLAGHAT-MARIANI (AS)-1	AEGCL	D	Corridor cleaning	04/Dec/2024	09:00	04/Dec/2024	15:00	01/Dec/2024 10:47	03/Dec/2024 10:26	47 Hours 39 Minutes
150	OCC_220	POWERGRID	132 KV, 50 MVA ICT 2 BAY AT SALAKATI	POWERGRID	D	For DCRM & Timing Measurement of CB. 132kv side (LV) of 50MVA ICT-II will charged through 132kv TBC bay. There will no outage of ICT-II.	04/Dec/2024	08:00	04/Dec/2024	16:00	01/Dec/2024 08:48	03/Dec/2024 10:26	48 Hours 26 Minutes
151	OCC_220	POWERGRID	TIE BAY (417) OF 400KV-BALIPARA-BONGAIGAON-2 AND 400KV-BISWANATH CHARIALI-BALIPARA-4 @BALIPARA - 400KV	POWERGRID	D	AMP works	04/Dec/2024	08:00	04/Dec/2024	16:00	01/Dec/2024 08:48	03/Dec/2024 10:26	48 Hours 26 Minutes
152	OCC_220	POWERGRID	400KV/220KV MARIANI (PG)-ICT-1	POWERGRID	D	AMP of ICT	04/Dec/2024	08:00	04/Dec/2024	16:00	01/Dec/2024 08:48	03/Dec/2024 10:26	48 Hours 26 Minutes
153	OCC_220	POWERGRID	132KV-KHANDONG-KOPILI -2	POWERGRID	D	Warranty test for GIS equipments	04/Dec/2024	08:00	04/Dec/2024	16:00	01/Dec/2024 08:48	03/Dec/2024 10:26	48 Hours 26 Minutes
154	OCC_220	MEPTCL	220KV-BYRNIHAT (KILLING)-MISA-1	MEPTCL	D	For Lines maintenance works	04/Dec/2024	08:00	04/Dec/2024	16:00	01/Dec/2024 01:38	03/Dec/2024 10:26	48 Hours 26 Minutes
155	OCC_220	MEPTCL	220KV-BYRNIHAT (KILLING)-MISA-2	MEPTCL	D	For Lines maintenance works	04/Dec/2024	08:00	04/Dec/2024	16:00	01/Dec/2024 01:39	03/Dec/2024 10:26	48 Hours 26 Minutes
156	OCC_220	NAGALAND	132KV-MOKOKCHUNG (PG)-MOKOKCHUNG-1	POWERGRID	D	132kv Main and Transfer bus jumper connection to 132kv New Zunheboto bay(NERPSIP)	03/Dec/2024	08:00	03/Dec/2024	13:00	01/Dec/2024 01:39	03/Dec/2024 10:26	48 Hours 26 Minutes
157	OCC_220	NAGALAND	132KV-MOKOKCHUNG (PG)-MOKOKCHUNG-2	POWERGRID	D	132kv Main and Transfer bus jumper connection to 132kv New Zunheboto bay(NERPSIP)	03/Dec/2024	08:00	03/Dec/2024	13:00	01/Dec/2024 01:39	03/Dec/2024 10:26	48 Hours 26 Minutes
158	OCC_220	NAGALAND	132KV-DOYANG-MOKOKCHUNG-1	NAGALAND, DOP	D	132kv Main and Transfer bus jumper connection to 132kv New Zunheboto bay(NERPSIP)	03/Dec/2024	08:00	03/Dec/2024	13:00	01/Dec/2024 01:39	03/Dec/2024 10:26	48 Hours 26 Minutes
159	OCC_220	AEGCL	132KV-GOHPUR-PAVOI-1	AEGCL	D	Corridor cleaning	03/Dec/2024	09:30	03/Dec/2024	15:00	30/Nov/2024 10:44	02/Dec/2024 10:59	48 Hours 15 Minutes
160	OCC_220	POWERGRID	400 KV AZARA BAY AT BONGAIGAON	POWERGRID	D	AMP of bay equipment	03/Dec/2024	09:00	03/Dec/2024	16:00	30/Nov/2024 09:06	02/Dec/2024 10:59	48 Hours 59 Minutes
161	OCC_220	AEGCL	220KV-AGIA-BTPS-2	AEGCL	D	Corridor cleaning	03/Dec/2024	09:00	03/Dec/2024	16:00	30/Nov/2024 10:12	02/Dec/2024 10:59	48 Hours 47 Minutes
162	OCC_220	POWERGRID	MAIN BAY () OF 400KV/220KV MARIANI (PG)-ICT-1 @MARIANI (PG) - 400KV(406)	POWERGRID	D	AMP of bay equipment	03/Dec/2024	08:00	03/Dec/2024	16:00	30/Nov/2024 09:06	02/Dec/2024 10:59	48 Hours 59 Minutes

सहायक

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

163	OCC_220	POWERGRID	BUS SECTIONALIZER BAY () OF BISWANATH CHARIALI - 400KV - BUS 3(2A) AND BISWANATH CHARIALI - 400KV - BUS 4(2B) @BISWANATH CHARIALI - 400KV	POWERGRID	D	AMP of bay equipment	03/Dec/2024	09:00	03/Dec/2024	16:00	30/Nov/2024 09:06	01/Dec/2024 11:42	26 Hours 36 Minutes
164	OCC_220	POWERGRID	132KV-KHLIEHRIAT(ME)-KHLIEHRIAT-1	POWERGRID	D	FOR AMP WORKS	03/Dec/2024	08:00	03/Dec/2024	16:00	30/Nov/2024 09:06	02/Dec/2024 10:59	48 Hours 59 Minutes
165	OCC_220	MEPTCL	AMPATI - 132KV - BUS 1	MEHGALAYA	D	Preventive Maintenance work	03/Dec/2024	08:00	03/Dec/2024	12:00	30/Nov/2024 03:44	02/Dec/2024 10:59	48 Hours 59 Minutes
166	OCC_220	POWERGRID	132KV-KHANDONG-KHLIEHRIAT-2	POWERGRID	C	For Re-conductoring of the existing single AAAC Panther with ACCC HTLS Conductor under NERES-XX Project	01/Dec/2024	00:00	31/Dec/2024	23:59	29/Nov/2024 10:21	01/Dec/2024 11:49	49 Hours 28 Minutes
167	OCC_220	NEEPCO	AGBPP - GTG 4	NEEPCO	C	Retrofitting,testing and commissioning works of new 216 kV,10 kA station Medium Duty Gapless (Type-Polymer) Surge Arrester (LA)	02/Dec/2024	08:00	04/Dec/2024	23:59	30/Nov/2024 08:14	01/Dec/2024 11:49	27 Hours 35 Minutes
168	OCC_220	POWERGRID	BUS SECTIONALIZER BAY () OF BISWANATH CHARIALI - 400KV - BUS 1(1A) AND BISWANATH CHARIALI - 400KV - BUS 2(1B) @BISWANATH CHARIALI - 400KV	POWERGRID	D	AMP of bay equipment	02/Dec/2024	09:00	02/Dec/2024	16:00	29/Nov/2024 10:21	30/Nov/2024 17:03	30 Hours 42 Minutes
169	OCC_220	POWERGRID	MARIANI (PG) - 400KV B/R 2	POWERGRID	D	AMP of bay equipment	02/Dec/2024	08:00	02/Dec/2024	16:00	29/Nov/2024 10:21	01/Dec/2024 11:49	49 Hours 28 Minutes
170	OCC_220	POWERGRID	132KV-KOPILI-KHLIEHRIAT-1	POWERGRID	D	Warranty test for GIS equipments	02/Dec/2024	08:00	02/Dec/2024	16:00	29/Nov/2024 10:21	01/Dec/2024 11:49	49 Hours 28 Minutes
171	OCC_220	NEEPCO	TUIRIAL - UNIT 2	NEEPCO	C	Annual Planned Maintenance	02/Dec/2024	00:00	15/Dec/2024	23:00	29/Nov/2024 10:21	01/Dec/2024 11:49	49 Hours 28 Minutes
172	OCC_220	AEGCL	220KV/132KV RANGIA -ICT-1	AEGCL	C	"Commissioning of the new 200 MVA Transformer. (Removal of the existing 100 MVA Transformer, Demolition of the Existing Transformer Pad, Construction of New Transformer, Foundation for 200 MVA Transformer including Curing time for the Transformer Pad and thereon Erection, Testing & Commissioning of the new 200 MVA Transformer.)"	01/Dec/2024	08:00	28/Feb/2025	17:00	28/11/2024 10:28	30/Nov/2024 08:52	46 Hours 19 Minutes
173	OCC_220	Arunachal Pradesh	132KV-TIPPI-TENGA-1	ARUNACHAL PRADESH	C	For replacement of damaged towers 157 and 158	01/Dec/2024	08:00	20/Dec/2024	17:00	28/11/2024 10:28	30/Nov/2024 08:27	46 Hours 19 Minutes
174	OCC_220	Arunachal Pradesh	132KV-BALIPARA-TENGA-1	ARUNACHAL PRADESH	D	"Isolate the Tippi-Tenga segment by opening the jumper near Tippi. Energize the Balipara-Tippi segment from Balipara end. Commence tower replacement activities"	01/Dec/2024	08:00	01/Dec/2024	12:00	28/11/2024 10:28	30/Nov/2024 08:27	46 Hours 19 Minutes
175	OCC_220	NEEPCO	132KV-PARE-ITANAGAR-2	NEEPCO,ARUNACHAL PRADESH	D	Vegetation Clearance in LILOPortion of 132kv Pare-Itanagar and 132kv Pare-Ranganadi (PLHPS) Line	01/Dec/2024	06:00	01/Dec/2024	14:00	28/11/2024 10:28	30/Nov/2024 08:27	46 Hours 19 Minutes
176	OCC_220	NEEPCO	132KV-RANGANADI-PARE-1	POWERGRID	D	Vegetation Clearance in LILOPortion of 132kv Pare-Itanagar and 132kv Pare-Ranganadi (PLHPS) Line	01/Dec/2024	06:00	01/Dec/2024	14:00	28/11/2024 10:28	30/Nov/2024 08:27	46 Hours 19 Minutes
177	OCC_220	NEEPCO	KOPILI - UNIT 2	NEEPCO	C	Annual Planned Maintenance	01/Dec/2024	00:00	15/Dec/2024	23:00	28/11/2024 10:28	30/Nov/2024 08:27	46 Hours 19 Minutes

सक्षम

सक्षम रिठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)