

**जनवरी '25 माह के लिए ओसीसी द्वारा अनुमोदित शटडाउन
OCC Approved Shutdowns for the month of January '25**

| क्रम संख्या/ Sl. No. | ओसीसी संख्या/ OCC Number | अनुरोधकर्ता एजेंसी का नाम/ Name of Requesting Agency | तत्व का नाम/ Element Name | धारक/ Owner | दैनिक/निरंतर Daily/ Continuous | कारण/ Reason | आरएलडीसी द्वारा अनुमोदित आरंभ तिथि/ RLDC Approved Start Date | आरएलडीसी स्वीकृत प्रारंभ समय/ RLDC Approved Start Time | आरएलडीसी द्वारा अनुमोदित अंतिम तिथि/ RLDC Approved End Date | आरएलडीसी द्वारा अनुमोदित समाप्ति समय/ RLDC Approved End Time | डी-3 पुष्टिकरण तिथि और समय/ D-3 Confirmation Date and Time | आरएलडीसी संसाधित समय/ RLDC Processed Time | शटडाउन समन्वय प्रक्रिया समय/ Shutdown Co-ordination Process Time |
|-------------------------|-----------------------------|---|--|----------------|-----------------------------------|---|---|---|--|---|---|--|---|
| 1 | OCC_221 | AEGCL | 220KV-AGIA-BOKO-1 | AEGCL | D | CORRIDOR CLEANING | 31/Jan/2025 | 09:00 | 31/Jan/2025 | 16:00 | 28/Jan/2025 22:32 | 30/Jan/2025 10:56 | 36 Hours 24 Minutes |
| 2 | OCC_221 | POWERGRID | AIZWAL - 132KV B/R 1 | POWERGRID | D | Shutdown of 132kV Bus Reactor of Aizawl to execute AMP of Reactor along with Hot Oil Circulation of NE Oil along with FDS measurement. | 31/Jan/2025 | 09:00 | 31/Jan/2025 | 17:00 | 28/Jan/2025 11:00 | 30/Jan/2025 10:56 | 47 Hours 56 Minutes |
| 3 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 31/Jan/2025 | 08:00 | 31/Jan/2025 | 16:00 | 28/Jan/2025 11:00 | 30/Jan/2025 10:56 | 47 Hours 56 Minutes |
| 4 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-2 | POWERGRID | D | Installation of TLA at different location | 31/Jan/2025 | 00:00 | 31/Jan/2025 | 08:17 | 28/Jan/2025 11:00 | 30/Jan/2025 10:56 | 47 Hours 56 Minutes |
| 5 | OCC_221 | POWERGRID | AIZWAL - 132KV B/R 1 | POWERGRID | D | Shutdown of 132kV Bus Reactor of Aizawl to execute AMP of Reactor along with Hot Oil Circulation of NE Oil along with FDS measurement. | 30/Jan/2025 | 09:00 | 30/Jan/2025 | 17:00 | 27/Jan/2025 09:07 | 29/Jan/2025 11:25 | 49 Hours 25 Minutes |
| 6 | OCC_221 | AEGCL | 220KV-AGIA-AZARA-1 | AEGCL | D | CORRIDOR CLEANING | 30/Jan/2025 | 09:00 | 30/Jan/2025 | 16:00 | 27/Jan/2025 11:59 | 29/Jan/2025 11:25 | 47 Hours 26 Minutes |
| 7 | OCC_221 | POWERGRID | 220KV/132KV MOKOKCHUNG (PG)-ICT-3 | POWERGRID | D | AMP works | 30/Jan/2025 | 09:00 | 30/Jan/2025 | 17:00 | 27/Jan/2025 09:07 | 29/Jan/2025 11:25 | 49 Hours 25 Minutes |
| 8 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 30/Jan/2025 | 08:00 | 30/Jan/2025 | 16:00 | 27/Jan/2025 09:07 | 29/Jan/2025 11:25 | 49 Hours 25 Minutes |
| 9 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-2 | POWERGRID | D | Installation of TLA at different location | 30/Jan/2025 | 00:00 | 30/Jan/2025 | 08:17 | 27/Jan/2025 09:07 | 29/Jan/2025 11:25 | 49 Hours 25 Minutes |
| 10 | OCC_221 | POWERGRID | AIZWAL - 132KV B/R 1 | POWERGRID | D | Shutdown of 132kV Bus Reactor of Aizawl to execute AMP of Reactor along with Hot Oil Circulation of NE Oil along with FDS measurement. | 29/Jan/2025 | 09:00 | 29/Jan/2025 | 17:00 | 26/Jan/2025 09:39 | 28/Jan/2025 10:39 | 48 Hours 39 Minutes |
| 11 | OCC_221 | AEGCL | 220KV-AGIA-BOKO-1 | AEGCL | D | CORRIDOR CLEANING | 29/Jan/2025 | 09:00 | 29/Jan/2025 | 16:00 | 26/Jan/2025 10:08 | 28/Jan/2025 10:39 | 48 Hours 31 Minutes |
| 12 | OCC_221 | POWERGRID | 400KV-SILCHAR-PK BARI (STERLITE)-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 29/Jan/2025 | 09:00 | 29/Jan/2025 | 17:00 | 26/Jan/2025 09:39 | 28/Jan/2025 10:39 | 48 Hours 39 Minutes |
| 13 | OCC_221 | POWERGRID | 400,125 MVAR BUS REACTOR 3 BAY AT BALIPARA | POWERGRID | D | AMP works | 29/Jan/2025 | 09:00 | 29/Jan/2025 | 17:00 | 26/Jan/2025 09:39 | 28/Jan/2025 10:39 | 48 Hours 39 Minutes |
| 14 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 29/Jan/2025 | 08:00 | 29/Jan/2025 | 16:00 | 26/Jan/2025 09:39 | 28/Jan/2025 10:39 | 48 Hours 39 Minutes |

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|----|---------|-----------|---------------------------------|-----------|---|--|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 15 | OCC_221 | AEGCL | 132KV-GOHPUR-NALKATA-2 | POWERGRID | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 29/Jan/2025 | 07:00 | 29/Jan/2025 | 14:00 | 26/Jan/2025 10:08 | 28/Jan/2025 10:39 | 48 Hours 31 Minutes |
| 16 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-2 | POWERGRID | D | Installation of TLA at different location | 29/Jan/2025 | 00:00 | 29/Jan/2025 | 08:17 | 26/Jan/2025 09:39 | 28/Jan/2025 10:39 | 48 Hours 39 Minutes |
| 17 | OCC_221 | POWERGRID | FILTER BANK 3 SUB BANK 2 at BNC | POWERGRID | D | AMP of bay equipment | 28/Jan/2025 | 09:00 | 28/Jan/2025 | 17:00 | 25/Jan/2025 10:56 | 27/Jan/2025 11:06 | 48 Hours 10 Minutes |
| 18 | OCC_221 | POWERGRID | 400KV/220KV MISA-ICT-1 | POWERGRID | D | AMP work | 28/Jan/2025 | 09:00 | 28/Jan/2025 | 17:00 | 25/Jan/2025 10:56 | 27/Jan/2025 11:06 | 48 Hours 10 Minutes |
| 19 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 28/Jan/2025 | 08:00 | 28/Jan/2025 | 16:00 | 25/Jan/2025 10:56 | 27/Jan/2025 11:06 | 48 Hours 10 Minutes |
| 20 | OCC_221 | AEGCL | 132KV-GOHPUR-NALKATA-1 | POWERGRID | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 28/Jan/2025 | 07:00 | 28/Jan/2025 | 14:00 | 25/Jan/2025 10:56 | 27/Jan/2025 11:06 | 48 Hours 10 Minutes |
| 21 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-2 | POWERGRID | D | Installation of TLA at different location | 28/Jan/2025 | 00:00 | 28/Jan/2025 | 08:17 | 25/Jan/2025 10:56 | 27/Jan/2025 11:06 | 48 Hours 10 Minutes |
| 22 | OCC_221 | POWERGRID | FILTER BANK 3 SUB BANK 1 at BNC | POWERGRID | D | AMP of bay equipment | 27/Jan/2025 | 09:00 | 27/Jan/2025 | 17:00 | 24/Jan/2025 08:22 | 25/Jan/2025 11:51 | 27 Hours 29 Minutes |
| 23 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-1 | POWERGRID | D | Installation of TLA at different location | 27/Jan/2025 | 08:00 | 27/Jan/2025 | 17:00 | 24/Jan/2025 08:22 | 26/Jan/2025 10:57 | 48 Hours 57 Minutes |
| 24 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 27/Jan/2025 | 08:00 | 27/Jan/2025 | 16:00 | 24/Jan/2025 08:22 | 26/Jan/2025 10:57 | 48 Hours 57 Minutes |
| 25 | OCC_221 | POWERGRID | 132KV-PASIGHAT-ROING-1 | POWERGRID | D | OPGW Stringing works in the diversion works carried out between span no 211 to 217 under crossing of Dotung river by using boats. Huge work involved for transporting of men and materials during the work through boat only. Best efforts shall be made for completion at the earliest for reduction of the proposed SD period. | 27/Jan/2025 | 08:00 | 27/Jan/2025 | 16:00 | 24/Jan/2025 08:22 | 26/Jan/2025 10:57 | 48 Hours 57 Minutes |
| 26 | OCC_221 | AEGCL | 220KV-JAWAHARNAGAR-SAMAGURI-1 | AEGCL | D | CORRIDOR CLEANING | 27/Jan/2025 | 07:00 | 27/Jan/2025 | 16:00 | 24/Jan/2025 11:52 | 26/Jan/2025 10:57 | 47 Hours 5 Minutes |
| 27 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-1 | POWERGRID | D | Installation of TLA at different location | 26/Jan/2025 | 08:00 | 26/Jan/2025 | 17:00 | 23/Jan/2025 08:58 | 25/Jan/2025 11:23 | 49 Hours 23 Minutes |

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रंशी

चित्रंशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|----|---------|-----------|---|-------------|---|--|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 28 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 26/Jan/2025 | 08:00 | 26/Jan/2025 | 16:00 | 23/Jan/2025 08:58 | 25/Jan/2025 11:23 | 49 Hours 23 Minutes |
| 29 | OCC_221 | POWERGRID | AIZWAL - 132KV B/R 1 | POWERGRID | D | Shutdown of 132KV Bus Reactor of Aizawl to execute AMP of Reactor along with Hot Oil Circulation of NE Oil along with FDS measurement. | 25/Jan/2025 | 09:00 | 25/Jan/2025 | 17:00 | 22/Jan/2025 08:57 | 24/Jan/2025 10:56 | 48 Hours 56 Minutes |
| 30 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-1 | POWERGRID | D | Installation of TLA at different location | 25/Jan/2025 | 08:00 | 25/Jan/2025 | 17:00 | 22/Jan/2025 08:57 | 24/Jan/2025 10:56 | 48 Hours 56 Minutes |
| 31 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 25/Jan/2025 | 08:00 | 25/Jan/2025 | 16:00 | 22/Jan/2025 08:57 | 24/Jan/2025 10:56 | 48 Hours 56 Minutes |
| 32 | OCC_221 | POWERGRID | AIZWAL - 132KV B/R 1 | POWERGRID | C | Shutdown of 132KV Bus Reactor of Aizawl to execute AMP of Reactor along with Hot Oil Circulation of NE Oil along with FDS measurement. | 24/Jan/2025 | 09:00 | 31/Jan/2025 | 17:00 | 21/Jan/2025 09:06 | 23/Jan/2025 10:56 | 48 Hours 47 Minutes |
| 33 | OCC_221 | POWERGRID | MAIN BAY (220) OF 220KV/132KV BALIPARA-ICT-2 AND @BALIPARA - 220KV | POWERGRID | D | AMP works | 24/Jan/2025 | 09:00 | 24/Jan/2025 | 17:00 | 21/Jan/2025 09:06 | 23/Jan/2025 10:56 | 48 Hours 47 Minutes |
| 34 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-1 | POWERGRID | D | Installation of TLA at different location | 24/Jan/2025 | 08:00 | 24/Jan/2025 | 17:00 | 21/Jan/2025 09:06 | 23/Jan/2025 10:56 | 48 Hours 47 Minutes |
| 35 | OCC_221 | AEGCL | 220KV-SAMAGURI-SONABIL-1 | AEGCL | D | TESTING OF SWITCHYARD EQUIPMENT AT SONABIL END & CORRDIOR CLEANING | 24/Jan/2025 | 08:00 | 24/Jan/2025 | 16:00 | 21/Jan/2025 09:06 | 23/Jan/2025 10:56 | 48 Hours 47 Minutes |
| 36 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 24/Jan/2025 | 08:00 | 24/Jan/2025 | 16:00 | 21/Jan/2025 09:06 | 23/Jan/2025 10:56 | 48 Hours 47 Minutes |
| 37 | OCC_221 | POWERGRID | SILCHAR - 132KV - BUS 1 | POWERGRID | D | •AMP of BUS and BUS CVT •Cleaning and Tightening works (All elments will be in service through Bus-2) | 24/Jan/2025 | 08:00 | 24/Jan/2025 | 16:00 | 21/Jan/2025 09:06 | 23/Jan/2025 10:56 | 48 Hours 47 Minutes |
| 38 | OCC_221 | AEGCL | 132KV-DHARMANAGAR (MISSION TILLA)-DULLAVCHERRA-1 | AEGCL,TSECL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK | 23/Jan/2025 | 09:00 | 23/Jan/2025 | 15:00 | 20/Jan/2025 12:10 | 22/Jan/2025 12:03 | 47 Hours 53 Minutes |
| 39 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-1 | POWERGRID | D | Installation of TLA at different location | 23/Jan/2025 | 08:00 | 23/Jan/2025 | 17:00 | 20/Jan/2025 11:18 | 22/Jan/2025 12:03 | 48 Hours 45 Minutes |
| 40 | OCC_221 | POWERGRID | 132KV-MOKOKCHUNG (PG)-MOKOKCHUNG-2 | POWERGRID | D | FOR AMP WORKS AT STATE END | 23/Jan/2025 | 08:00 | 23/Jan/2025 | 16:00 | 20/Jan/2025 11:18 | 22/Jan/2025 12:03 | 48 Hours 45 Minutes |
| 41 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 23/Jan/2025 | 08:00 | 23/Jan/2025 | 16:00 | 20/Jan/2025 11:18 | 22/Jan/2025 12:03 | 48 Hours 45 Minutes |
| 42 | OCC_221 | AEGCL | 220KV-SAMAGURI-SONAPUR-1 | AEGCL | D | CORRIDOR CLEANING | 23/Jan/2025 | 08:00 | 23/Jan/2025 | 16:00 | 20/Jan/2025 12:10 | 22/Jan/2025 12:03 | 47 Hours 53 Minutes |
| 43 | OCC_221 | POWERGRID | MARIANI (PG) - 400KV - BUS 2 | POWERGRID | D | AMP of Bay equipments | 22/Jan/2025 | 09:00 | 22/Jan/2025 | 17:00 | 19/Jan/2025 09:08 | 21/Jan/2025 10:45 | 49 Hours 37 Minutes |
| 44 | OCC_221 | POWERGRID | MAIN BAY (415) OF MARIANI (PG) - 400KV - FUTURE - 2 @MARIANI (PG) - 400KV | POWERGRID | D | AMP of Bay equipments | 22/Jan/2025 | 09:00 | 22/Jan/2025 | 17:00 | 19/Jan/2025 09:08 | 21/Jan/2025 10:45 | 49 Hours 37 Minutes |
| 45 | OCC_221 | POWERGRID | TIE BAY () OF 400KV-BISWANATH CHARIALI-SUBANSIRI-1 AND 400KV-BISWANATH CHARIALI-SUBANSIRI-2 @BISWANATH CHARIALI - 400KV | POWERGRID | D | AMP of bay equipment | 22/Jan/2025 | 09:00 | 22/Jan/2025 | 16:00 | 19/Jan/2025 09:08 | 21/Jan/2025 10:45 | 49 Hours 37 Minutes |

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|----|---------|-----------|--|--------------|---|--|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 46 | OCC_221 | AEGCL | 132KV-DHARMANAGAR (MISSION TILLA)-DULLAVCHERRA-1 | AEGCL,TSECL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK | 22/Jan/2025 | 09:00 | 22/Jan/2025 | 15:00 | 19/Jan/2025 09:08 | 21/Jan/2025 12:12 | 48 Hours 17 Minutes |
| 47 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 22/Jan/2025 | 08:00 | 22/Jan/2025 | 16:00 | 19/Jan/2025 09:08 | 21/Jan/2025 10:45 | 49 Hours 37 Minutes |
| 48 | OCC_221 | AEGCL | 220KV-NTPS-AMGURI-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 22/Jan/2025 | 08:00 | 22/Jan/2025 | 16:00 | 19/Jan/2025 09:08 | 21/Jan/2025 10:45 | 49 Hours 37 Minutes |
| 49 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-1 | POWERGRID | D | Installation of TLA at different location | 22/Jan/2025 | 08:00 | 22/Jan/2025 | 17:00 | 19/Jan/2025 09:08 | 21/Jan/2025 10:45 | 49 Hours 37 Minutes |
| 50 | OCC_221 | AEGCL | 220KV-SONAPUR-SARUSAJAI-1 | AEGCL | D | CORRIDOR CLEANING | 22/Jan/2025 | 08:00 | 22/Jan/2025 | 16:00 | 19/Jan/2025 09:08 | 21/Jan/2025 10:45 | 49 Hours 37 Minutes |
| 51 | OCC_221 | POWERGRID | 400/132 KV 200 MVA ICT I AND 400/132 KV 200 MVA ICT II AT BISWANATH CHARIALI | POWERGRID | D | AMP of bay equipment | 21/Jan/2025 | 09:00 | 21/Jan/2025 | 16:00 | 18/Jan/2025 09:16 | 20/Jan/2025 10:34 | 48 Hours 34 Minutes |
| 52 | OCC_221 | POWERGRID | MAIN BAY (412) OF MARIANI (PG) - 400KV B/R 2 AND @MARIANI (PG) - 400KV | POWERGRID | D | AMP of Bay equipments | 21/Jan/2025 | 09:00 | 21/Jan/2025 | 17:00 | 18/Jan/2025 09:16 | 20/Jan/2025 10:34 | 48 Hours 34 Minutes |
| 53 | OCC_221 | AEGCL | 132KV-HAILAKANDI-DULLAVCHERRA-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK | 21/Jan/2025 | 09:00 | 21/Jan/2025 | 16:00 | 18/Jan/2025 10:58 | 20/Jan/2025 10:34 | 47 Hours 36 Minutes |
| 54 | OCC_221 | POWERGRID | MAIN BAY (02) OF 400KV/220KV MISA-ICT-2 @MISA - 400KV | POWERGRID | D | AMP of Bay equipments | 21/Jan/2025 | 09:00 | 21/Jan/2025 | 17:00 | 18/Jan/2025 09:16 | 20/Jan/2025 10:34 | 48 Hours 34 Minutes |
| 55 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 21/Jan/2025 | 08:00 | 21/Jan/2025 | 16:00 | 18/Jan/2025 09:16 | 20/Jan/2025 10:34 | 48 Hours 34 Minutes |
| 56 | OCC_221 | AEGCL | 220KV-NTPS-AMGURI-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 21/Jan/2025 | 08:00 | 21/Jan/2025 | 16:00 | 18/Jan/2025 10:58 | 20/Jan/2025 10:34 | 47 Hours 36 Minutes |
| 57 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-1 | POWERGRID | D | Installation of TLA at different location | 21/Jan/2025 | 08:00 | 21/Jan/2025 | 17:00 | 18/Jan/2025 09:16 | 20/Jan/2025 10:34 | 48 Hours 34 Minutes |
| 58 | OCC_221 | POWERGRID | 132KV-MOKOKCHUNG (PG)-MOKOKCHUNG-1 | POWERGRID | D | FOR AMP WORKS AT STATE END | 21/Jan/2025 | 08:00 | 21/Jan/2025 | 16:00 | 18/Jan/2025 09:16 | 20/Jan/2025 10:34 | 48 Hours 34 Minutes |
| 59 | OCC_221 | POWERGRID | SILCHAR - 400KV - BUS 2 | POWERGRID | D | •AMP of BUS and BUS CVT •Cleaning and Tightening works (All elements will be in service through Bus-1) | 21/Jan/2025 | 08:00 | 21/Jan/2025 | 16:00 | 18/Jan/2025 09:16 | 20/Jan/2025 10:34 | 48 Hours 34 Minutes |
| 60 | OCC_221 | AEGCL | 220KV-SAMAGURI-SONAPUR-1 | AEGCL | D | CORRIDOR CLEANING | 21/Jan/2025 | 08:00 | 21/Jan/2025 | 16:00 | 18/Jan/2025 12:10 | 20/Jan/2025 10:34 | 46 Hours 24 Minutes |
| 61 | OCC_221 | AEGCL | 132KV-GOHPUR-NALKATA-2 | POWERGRID | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 21/Jan/2025 | 07:00 | 21/Jan/2025 | 14:00 | 18/Jan/2025 10:58 | 20/Jan/2025 10:34 | 47 Hours 36 Minutes |
| 62 | OCC_221 | POWERGRID | 400 KV BISWANATH CHARIALI 2 MAIN BAY(WITH 50 MVAR LINE REACTOR)(407) AT BALIPARA | POWERGRID | D | AMP works | 20/Jan/2025 | 09:00 | 20/Jan/2025 | 17:00 | 17/Jan/2025 10:13 | 19/Jan/2025 11:50 | 49 Hours 37 Minutes |
| 63 | OCC_221 | AEGCL | 220KV-AGIA-BTPS-1 | AEGCL | D | CORRIDOR CLEANING | 20/Jan/2025 | 08:00 | 20/Jan/2025 | 16:00 | 17/Jan/2025 10:43 | 19/Jan/2025 11:50 | 49 Hours 7 Minutes |
| 64 | OCC_221 | POWERGRID | TIE BAY (W14Q2) OF HVDC 800KV BISWANATH CHARIALI POLE 1 AND FUTURE @BISWANATH CHARIALI - 800KV | POWERGRID | D | AMP of bay equipment | 20/Jan/2025 | 09:00 | 20/Jan/2025 | 16:00 | 17/Jan/2025 10:13 | 18/Jan/2025 11:06 | 24 Hours 53 Minutes |
| 65 | OCC_221 | POWERGRID | BONGAIGAON - 400KV - BUS 2 | POWERGRID | C | 1. CT wiring shall be done at CT JB for Main#1 & 2 Busbar Relay (from Main Bay CT Core #1 & 2). 2. Busbar Stability test 3. Busbar testing and tripping shall be verified. | 20/Jan/2025 | 09:00 | 22/Jan/2025 | 21:00 | 17/Jan/2025 10:13 | 19/Jan/2025 11:50 | 49 Hours 37 Minutes |
| 66 | OCC_221 | NAGALAND | 132KV-DIMAPUR(PG)-KOHIMA-1 | NAGALAND,DOP | D | Vegetation clearance | 20/Jan/2025 | 09:00 | 20/Jan/2025 | 15:00 | 17/Jan/2025 07:58 | 19/Jan/2025 11:50 | 49 Hours 50 Minutes |

Saksham Rithe

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

Chitranshi Ghangrekar

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|----|---------|-----------|------------------------------------|-----------|---|---|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 67 | OCC_221 | POWERGRID | 132KV-SILCHAR-HAILAKANDI-1 | POWERGRID | D | Installation of TLA at different location | 20/Jan/2025 | 08:00 | 20/Jan/2025 | 17:00 | 17/Jan/2025 10:13 | 19/Jan/2025 11:50 | 49 Hours 37 Minutes |
| 68 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 20/Jan/2025 | 08:00 | 20/Jan/2025 | 16:00 | 17/Jan/2025 10:13 | 19/Jan/2025 11:50 | 49 Hours 37 Minutes |
| 69 | OCC_221 | AEGCL | 132KV-GOHPUR-NALKATA-1 | POWERGRID | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 20/Jan/2025 | 07:00 | 20/Jan/2025 | 14:00 | 17/Jan/2025 10:43 | 19/Jan/2025 11:50 | 49 Hours 7 Minutes |
| 70 | OCC_221 | AEGCL | 220KV-JAWAHARNAGAR-SAMAGURI-1 | AEGCL | D | CORRIDOR CLEANING | 20/Jan/2025 | 07:00 | 20/Jan/2025 | 16:00 | 17/Jan/2025 10:43 | 19/Jan/2025 11:50 | 49 Hours 7 Minutes |
| 71 | OCC_221 | AEGCL | 220KV-BTPS-RANGIA-1 | AEGCL | C | Dismantling of existing Tower 453 for stringing of circuit-1 . stringing of Single Conductor (Circuit 1) between the tower 452-453 and 453-454 along with Dismantling of existing conductor | 19/Jan/2025 | 07:00 | 23/Jan/2025 | 17:00 | 16/Jan/2025 11:04 | 18/Jan/2025 11:22 | 48 Hours 18 Minutes |
| 72 | OCC_221 | AEGCL | 132KV-RUPAI-MARGHERITA_AS-1 | AEGCL | D | DOUBLE JUMPERING WORK AT LOC & CORRIDOR CLEANING WORK& | 19/Jan/2025 | 09:00 | 19/Jan/2025 | 15:00 | 16/Jan/2025 11:04 | 18/Jan/2025 11:22 | 48 Hours 18 Minutes |
| 73 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 19/Jan/2025 | 08:00 | 19/Jan/2025 | 16:00 | 16/Jan/2025 09:48 | 18/Jan/2025 11:22 | 49 Hours 22 Minutes |
| 74 | OCC_221 | POWERGRID | 400KV/132KV SILCHAR-ICT-2 | POWERGRID | D | • AMP of ICT and 132kv Bay Equipment • CB DCRM, CRM, Timing Testing, CT Tandelta testing, Bushing tandelta testing • Cleaning & Tightening works | 18/Jan/2025 | 09:00 | 18/Jan/2025 | 17:00 | 15/Jan/2025 10:13 | 17/Jan/2025 10:38 | 48 Hours 25 Minutes |
| 75 | OCC_221 | AEGCL | 220KV-BTPS-RANGIA-2 | AEGCL | D | stringing of Single Conductor (Circuit 2) between the tower 452-453 and 453-454 along with Dismantling of existing conductor | 18/Jan/2025 | 07:00 | 18/Jan/2025 | 17:00 | 15/Jan/2025 10:13 | 17/Jan/2025 10:38 | 48 Hours 25 Minutes |
| 76 | OCC_221 | AEGCL | 132KV-SRIKONA-PAILAPPOL-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK | 18/Jan/2025 | 09:00 | 18/Jan/2025 | 16:00 | 15/Jan/2025 10:13 | 17/Jan/2025 10:38 | 48 Hours 25 Minutes |
| 77 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 18/Jan/2025 | 08:00 | 18/Jan/2025 | 16:00 | 15/Jan/2025 08:29 | 17/Jan/2025 10:38 | 48 Hours 38 Minutes |
| 78 | OCC_221 | POWERGRID | 132KV-CHAPAKHOWA-ROING-2 | POWERGRID | D | FOR AMP WORKS AT ROING & CHAPKOWA END | 17/Jan/2025 | 08:00 | 17/Jan/2025 | 16:00 | 14/Jan/2025 08:52 | 16/Jan/2025 10:55 | 48 Hours 55 Minutes |
| 79 | OCC_221 | AEGCL | 220KV-AGIA-BTPS-2 | AEGCL | D | CORRIDOR CLEANING | 17/Jan/2025 | 08:00 | 17/Jan/2025 | 16:00 | 14/Jan/2025 11:21 | 16/Jan/2025 10:55 | 47 Hours 34 Minutes |
| 80 | OCC_221 | AEGCL | 220KV-AGBPP-TINSUKIA-2 | AEGCL | D | CORRIDOR CLEANING | 17/Jan/2025 | 10:00 | 17/Jan/2025 | 16:00 | 14/Jan/2025 11:21 | 16/Jan/2025 10:55 | 47 Hours 34 Minutes |
| 81 | OCC_221 | POWERGRID | 400KV-PALATANA-SILCHAR-1 | NETC | D | Firmware Upgradation of Bothe Main1 and Main2 distance relay and testing of the same. | 17/Jan/2025 | 08:00 | 17/Jan/2025 | 16:00 | 14/Jan/2025 08:52 | 16/Jan/2025 10:55 | 48 Hours 55 Minutes |
| 82 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 17/Jan/2025 | 08:00 | 17/Jan/2025 | 16:00 | 14/Jan/2025 08:52 | 16/Jan/2025 10:55 | 48 Hours 55 Minutes |
| 83 | OCC_221 | MEPTCL | 220KV-MAWNGAP-BYRNIHAT (KILLING)-1 | MEGHALAYA | D | For Lines maintenance works | 16/Jan/2025 | 08:00 | 16/Jan/2025 | 16:00 | 13/Jan/2025 00:28 | 16/Jan/2025 00:14 | 38 Hours 14 Minutes |
| 84 | OCC_221 | MEPTCL | 220KV-MAWNGAP-BYRNIHAT (KILLING)-2 | MEGHALAYA | D | For Lines maintenance works | 16/Jan/2025 | 08:00 | 16/Jan/2025 | 16:00 | 13/Jan/2025 00:30 | 16/Jan/2025 00:14 | 38 Hours 14 Minutes |
| 85 | OCC_221 | AEGCL | 220KV-BTPS-RANGIA-2 | AEGCL | C | stringing of Single Conductor (Circuit 2) between the tower 452-453 and 453-454 along with Dismantling of existing conductor | 16/Jan/2025 | 07:00 | 18/Jan/2025 | 17:00 | 13/Jan/2025 10:20 | 16/Jan/2025 00:14 | 38 Hours 14 Minutes |
| 86 | OCC_221 | POWERGRID | BONGAIGAON - 400KV - BUS 1 | POWERGRID | C | 1. CT wiring shall be done at CT JB for Main#1 & 2 Busbar Relay (from Main Bay CT Core #1 & 2). 2. Busbar Stability test 3. Busbar testing and tripping shall be verified. | 16/Jan/2025 | 09:00 | 18/Jan/2025 | 21:00 | 13/Jan/2025 11:51 | 16/Jan/2025 00:14 | 38 Hours 14 Minutes |

Saksham

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

Chitranshi

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|-----|---------|-----------|---|-----------|---|---|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 87 | OCC_221 | POWERGRID | MAIN BAY () OF 400KV-BALIPARA-MISA-2 @MISA - 400KV | POWERGRID | D | AMP of Bay equipments | 16/Jan/2025 | 09:00 | 16/Jan/2025 | 17:00 | 13/Jan/2025 11:51 | 16/Jan/2025 00:14 | 38 Hours 14 Minutes |
| 88 | OCC_221 | POWERGRID | 132KV-AIZWAL-TIPAIMUMK-1 | POWERGRID | D | Installation of TLA at different location | 16/Jan/2025 | 08:00 | 16/Jan/2025 | 16:00 | 13/Jan/2025 11:51 | 16/Jan/2025 00:14 | 38 Hours 14 Minutes |
| 89 | OCC_221 | POWERGRID | 132KV-CHAPAKHOWA-ROING-1 | POWERGRID | D | FOR AMP WORKS AT ROING & CHAPKOWA END | 16/Jan/2025 | 08:00 | 16/Jan/2025 | 16:00 | 13/Jan/2025 11:51 | 16/Jan/2025 00:14 | 38 Hours 14 Minutes |
| 90 | OCC_221 | INDIGRID | 400KV/132KV PK BARI (STERLITE)-ICT-2 | INDIGRID | D | AMP work | 15/Jan/2025 | 07:00 | 15/Jan/2025 | 17:00 | 12/Jan/2025 09:00 | 14/Jan/2025 10:19 | 48 Hours 19 Minutes |
| 91 | OCC_221 | MEPTCL | 220KV-MAWNGAP-BYRNHAT (KILLING)-1 | MEGHALAYA | D | For Lines maintenance works | 15/Jan/2025 | 08:00 | 15/Jan/2025 | 16:00 | 12/Jan/2025 00:27 | 14/Jan/2025 10:19 | 48 Hours 19 Minutes |
| 92 | OCC_221 | MEPTCL | 220KV-MAWNGAP-BYRNHAT (KILLING)-2 | MEGHALAYA | D | For Lines maintenance works | 15/Jan/2025 | 08:00 | 15/Jan/2025 | 16:00 | 12/Jan/2025 00:27 | 14/Jan/2025 10:19 | 48 Hours 19 Minutes |
| 93 | OCC_221 | POWERGRID | 400 KV, 80 MVAR BUS REACTOR 3 BAY AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 15/Jan/2025 | 09:00 | 15/Jan/2025 | 13:00 | 12/Jan/2025 11:06 | 14/Jan/2025 10:19 | 47 Hours 13 Minutes |
| 94 | OCC_221 | INDIGRID | 400KV/132KV PK BARI (STERLITE)-ICT-1 | INDIGRID | D | AMP work | 14/Jan/2025 | 07:00 | 14/Jan/2025 | 17:00 | 11/Jan/2025 08:43 | 13/Jan/2025 10:13 | 48 Hours 13 Minutes |
| 95 | OCC_221 | POWERGRID | 220KV-SALAKATI-ALIPURDUAR-2 | POWERGRID | D | FOR AMP WORKS | 13/Jan/2025 | 08:00 | 13/Jan/2025 | 16:00 | 10/Jan/2025 09:03 | 12/Jan/2025 10:23 | 48 Hours 23 Minutes |
| 96 | OCC_221 | POWERGRID | 400 KV BGTPP 1 BAY AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 13/Jan/2025 | 14:00 | 13/Jan/2025 | 17:00 | 10/Jan/2025 09:03 | 12/Jan/2025 10:23 | 48 Hours 23 Minutes |
| 97 | OCC_221 | AEGCL | 220KV-AGBPP-TINSUKIA-1 | AEGCL | D | CORRIDOR CLEANING | 13/Jan/2025 | 10:00 | 13/Jan/2025 | 16:00 | 10/Jan/2025 09:59 | 12/Jan/2025 10:23 | 48 Hours 23 Minutes |
| 98 | OCC_221 | POWERGRID | 400 KV AZARA BAY AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 13/Jan/2025 | 09:00 | 13/Jan/2025 | 13:00 | 10/Jan/2025 09:03 | 12/Jan/2025 10:23 | 48 Hours 23 Minutes |
| 99 | OCC_221 | POWERGRID | 220KV-MISA-SAMAGURI-2 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 13/Jan/2025 | 08:00 | 13/Jan/2025 | 16:00 | 10/Jan/2025 09:03 | 12/Jan/2025 10:23 | 48 Hours 23 Minutes |
| 100 | OCC_221 | POWERGRID | 400 KV BALIPARA 4 BAY (WITH 63 MVAR LINE REACTOR) AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 11/Jan/2025 | 14:00 | 11/Jan/2025 | 17:00 | 08/Jan/2025 08:41 | 10/Jan/2025 11:09 | 49 Hours 9 Minutes |
| 101 | OCC_221 | AEGCL | 220KV-BTPS-RANGIA-1 | AEGCL | D | Shutdown taken for maintaining adequate clearance as new tower will be erected at Loc no. 453. | 11/Jan/2025 | 07:00 | 11/Jan/2025 | 17:00 | 09/Jan/2025 10:54 | 10/Jan/2025 11:09 | 24 Hours 15 Minutes |
| 102 | OCC_221 | MEPTCL | 132KV-HATSINGIMARI-AMPATI-1 | STERLITE | D | Preventive maintenance Work | 11/Jan/2025 | 08:00 | 11/Jan/2025 | 10:00 | 08/Jan/2025 08:41 | 10/Jan/2025 11:09 | 49 Hours 9 Minutes |
| 103 | OCC_221 | MEPTCL | 132KV-HATSINGIMARI-AMPATI-2 | STERLITE | D | Preventive maintenance Work | 11/Jan/2025 | 08:00 | 11/Jan/2025 | 10:00 | 08/Jan/2025 08:41 | 10/Jan/2025 11:09 | 49 Hours 9 Minutes |
| 104 | OCC_221 | AEGCL | 220KV-MARIANI (AS)-SAMAGURI-2 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 11/Jan/2025 | 08:00 | 11/Jan/2025 | 16:00 | 08/Jan/2025 10:38 | 10/Jan/2025 11:09 | 48 Hours 31 Minutes |
| 105 | OCC_221 | POWERGRID | 400 KV ALIPURDUAR 1 BAY (415) AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 11/Jan/2025 | 09:00 | 11/Jan/2025 | 13:00 | 08/Jan/2025 13:21 | 10/Jan/2025 11:09 | 45 Hours 48 Minutes |
| 106 | OCC_221 | AEGCL | 220KV-BTPS-RANGIA-1 | AEGCL | D | Shutdown taken for maintaining adequate clearance as new tower will be erected at Loc no. 453. | 10/Jan/2025 | 07:00 | 10/Jan/2025 | 17:00 | 09/Jan/2025 11:27 | 10/Jan/2025 08:29 | 21 Hours 2 Minutes |

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|-----|---------|-----------|--|--------------|---|---|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 107 | OCC_221 | POWERGRID | 400 KV BALIPARA 2 BAY (WITH 63 MVAR LINE REACTOR) (412) AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 10/Jan/2025 | 14:00 | 10/Jan/2025 | 17:00 | 07/Jan/2025 12:18 | 09/Jan/2025 11:24 | 47 Hours 6 Minutes |
| 108 | OCC_221 | MEPTCL | LUMSNONG - 132KV - BUS 1 | MEPTCL | D | For general maintenance | 10/Jan/2025 | 10:00 | 10/Jan/2025 | 15:00 | 07/Jan/2025 10:15 | 09/Jan/2025 11:24 | 49 Hours 9 Minutes |
| 109 | OCC_221 | POWERGRID | 400KV-MISA-MARIANI (PG)-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 10/Jan/2025 | 09:00 | 10/Jan/2025 | 17:00 | 07/Jan/2025 12:18 | 09/Jan/2025 11:24 | 47 Hours 6 Minutes |
| 110 | OCC_221 | POWERGRID | MAIN BAY (W14Q1) OF HVDC 800KV BISWANATH CHARIALI POLE 1 @BISWANATH CHARIALI - 800KV | POWERGRID | D | AMP of bay equipment | 10/Jan/2025 | 09:00 | 10/Jan/2025 | 16:00 | 07/Jan/2025 12:18 | 08/Jan/2025 10:49 | 22 Hours 31 Minutes |
| 111 | OCC_221 | AEGCL | 220KV-AGIA-AZARA-1 | AEGCL | D | CORRIDOR CLEANING | 10/Jan/2025 | 09:00 | 10/Jan/2025 | 16:00 | 07/Jan/2025 12:09 | 09/Jan/2025 11:24 | 47 Hours 15 Minutes |
| 112 | OCC_221 | AEGCL | 132KV-RUPAI-CHAPAKHOWA-1 | AEGCL | D | CORRIDOR CLEANING | 10/Jan/2025 | 09:00 | 10/Jan/2025 | 16:00 | 07/Jan/2025 12:09 | 09/Jan/2025 11:24 | 47 Hours 15 Minutes |
| 113 | OCC_221 | POWERGRID | 220 KV, 50 MVA ICT 1 BAY AT SALAKATI | POWERGRID | D | AMP WORKS. ICT-1 will be in service through TBC bay | 10/Jan/2025 | 09:00 | 10/Jan/2025 | 17:00 | 07/Jan/2025 12:18 | 09/Jan/2025 11:24 | 47 Hours 6 Minutes |
| 114 | OCC_221 | AEGCL | 132KV-LUMSNONG-PANCHGRAM (NEW)-1 | MEPTCL,AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK | 10/Jan/2025 | 09:00 | 10/Jan/2025 | 16:00 | 07/Jan/2025 12:09 | 09/Jan/2025 11:24 | 47 Hours 15 Minutes |
| 115 | OCC_221 | POWERGRID | 400 KV, 50 MVAR BUS REACTOR 1 BAY AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 10/Jan/2025 | 09:00 | 10/Jan/2025 | 13:00 | 07/Jan/2025 12:18 | 09/Jan/2025 11:24 | 47 Hours 6 Minutes |
| 116 | OCC_221 | POWERGRID | 220KV/132KV BALIPARA-ICT-2 | POWERGRID | D | AMP works | 10/Jan/2025 | 09:00 | 10/Jan/2025 | 17:00 | 07/Jan/2025 12:18 | 09/Jan/2025 11:24 | 47 Hours 6 Minutes |
| 117 | OCC_221 | AEGCL | 220KV-MARIANI (AS)-SAMAGURI-2 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 10/Jan/2025 | 08:00 | 10/Jan/2025 | 16:00 | 07/Jan/2025 12:09 | 09/Jan/2025 11:24 | 47 Hours 15 Minutes |
| 118 | OCC_221 | POWERGRID | MAIN BAY (I) OF 400KV/220KV BONGAIGAON-ICT-2 @BONGAIGAON - 400KV | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 09/Jan/2025 | 09:00 | 09/Jan/2025 | 13:00 | 08/Jan/2025 12:14 | 09/Jan/2025 10:48 | 22 Hours 34 Minutes |
| 119 | OCC_221 | AEGCL | 220KV-BTPS-RANGIA-1 | AEGCL | D | Shutdown taken for maintaining adequate clearance as new tower will be erected at Loc no. 453. | 09/Jan/2025 | 07:00 | 09/Jan/2025 | 17:00 | 08/Jan/2025 12:14 | 09/Jan/2025 10:48 | 22 Hours 34 Minutes |
| 120 | OCC_221 | AEGCL | 220KV-BTPS-RANGIA-2 | AEGCL | D | Shutdown taken for maintaining adequate clearance as new tower will be erected at Loc no. 453. | 08/Jan/2025 | 07:00 | 08/Jan/2025 | 17:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 121 | OCC_221 | POWERGRID | 400KV-MISA-MARIANI (PG)-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 09/Jan/2025 | 09:00 | 09/Jan/2025 | 17:00 | 06/Jan/2025 11:48 | 08/Jan/2025 11:38 | 47 Hours 50 Minutes |
| 122 | OCC_221 | AEGCL | 220KV/132KV AGIA-ICT-2 | MEPTCL | D | ROUTINE TESTING | 09/Jan/2025 | 09:00 | 09/Jan/2025 | 16:00 | 06/Jan/2025 11:04 | 08/Jan/2025 11:38 | 48 Hours 34 Minutes |
| 123 | OCC_221 | POWERGRID | TIE BAY (I) OF 400KV-BISWANATH CHARIALI-BALIPARA-2 AND 400KV-BISWANATH CHARIALI-BALIPARA-4 @BISWANATH CHARIALI - 400KV | POWERGRID | D | AMP of bay equipment | 09/Jan/2025 | 09:00 | 09/Jan/2025 | 16:00 | 06/Jan/2025 09:06 | 08/Jan/2025 11:38 | 49 Hours 38 Minutes |
| 124 | OCC_221 | POWERGRID | 400 KV NEW SILIGURI 1 BAY (WITH 63 MVAR LINE REACTOR) (406) AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 09/Jan/2025 | 14:00 | 09/Jan/2025 | 17:00 | 06/Jan/2025 09:06 | 08/Jan/2025 11:38 | 49 Hours 38 Minutes |
| 125 | OCC_221 | NEEPCO | AGTCCPP - STG 2 | NEEPCO | C | Inspection of STG #2 to resolve the issue of high speed trip during Start up. | 09/Jan/2025 | 10:00 | 10/Jan/2025 | 23:00 | 06/Jan/2025 19:44 | 08/Jan/2025 11:38 | 39 Hours 54 Minutes |
| 126 | OCC_221 | AEGCL | 132KV-JIRIBAM(PG)-PAILAPPOL-1 | MSPCL,AEGCL | D | CORRIDOR CLEANING | 09/Jan/2025 | 09:00 | 09/Jan/2025 | 16:00 | 06/Jan/2025 11:04 | 08/Jan/2025 11:38 | 48 Hours 34 Minutes |
| 127 | OCC_221 | AEGCL | 132KV-SARUPATHAR-BOKAJAN-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 09/Jan/2025 | 09:00 | 09/Jan/2025 | 16:00 | 06/Jan/2025 11:04 | 08/Jan/2025 11:38 | 48 Hours 34 Minutes |

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|-----|---------|-----------|--|-----------------|---|---|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 128 | OCC_221 | AEGCL | 132KV-NIRJULI-NORTH LAKHIMPUR-1 | STERLITE | D | ROUTINE TESTING OF BAY EQUIPMENT | 09/Jan/2025 | 09:00 | 09/Jan/2025 | 16:00 | 06/Jan/2025 11:04 | 08/Jan/2025 11:38 | 48 Hours 34 Minutes |
| 129 | OCC_221 | POWERGRID | TRANSFER BUS COUPLER BAY (202) OF (SALAKATI - 220KV - BUS 1 & SALAKATI - 220KV - BUS 2) AND SALAKATI - 220KV - BUS 3 @SALAKATI - 220KV | POWERGRID | D | FOR BAY EQUIPMENT AMP WORK | 09/Jan/2025 | 09:00 | 09/Jan/2025 | 17:00 | 06/Jan/2025 13:07 | 08/Jan/2025 11:38 | 46 Hours 31 Minutes |
| 130 | OCC_221 | AEGCL | 132KV-LUMSNONG-PANCHGRAM (NEW)-1 | MEPTCL,AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK | 09/Jan/2025 | 09:00 | 09/Jan/2025 | 16:00 | 06/Jan/2025 11:04 | 08/Jan/2025 11:38 | 48 Hours 34 Minutes |
| 131 | OCC_221 | POWERGRID | 220KV-MISA-SAMAGURI-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 09/Jan/2025 | 08:00 | 09/Jan/2025 | 16:00 | 06/Jan/2025 09:49 | 08/Jan/2025 11:38 | 49 Hours 38 Minutes |
| 132 | OCC_221 | POWERGRID | MARIANI (PG) - 400KV - BUS 1 | POWERGRID | D | AMP of Bay equipments | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 17:00 | 06/Jan/2025 16:27 | 07/Jan/2025 12:19 | 19 Hours 52 Minutes |
| 133 | OCC_221 | POWERGRID | 400KV-MISA-MARIANI (PG)-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 17:00 | 05/Jan/2025 09:40 | 07/Jan/2025 12:19 | 50 Hours 19 Minutes |
| 134 | OCC_221 | MEPTCL | 220KV-BYRNHAT (KILLING)-MISA-1 | MEPTCL | D | For Lines maintenance works | 08/Jan/2025 | 08:00 | 08/Jan/2025 | 16:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 135 | OCC_221 | MEPTCL | 220KV-BYRNHAT (KILLING)-MISA-2 | MEPTCL | D | For Lines maintenance works | 08/Jan/2025 | 08:00 | 08/Jan/2025 | 16:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 136 | OCC_221 | POWERGRID | TIE BAY () OF 400KV-BISWANATH CHARIALI-BALIPARA-3 AND BISWANATH CHARIALI - 400KV B/R 1 @BISWANATH CHARIALI - 400KV | POWERGRID | D | AMP of bay equipment | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 16:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 137 | OCC_221 | POWERGRID | MAIN BAY (401) OF MARIANI (PG) - 400KV - FUTURE - 1 @MARIANI (PG) - 400KV | POWERGRID | D | AMP of Bay equipments | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 17:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 138 | OCC_221 | AEGCL | 132KV-UMTRU-SARUSAJAI-2 | MEPTCL | D | PREVENTIVE MAINTENANCE OF BAY EQUIPMENT | 08/Jan/2025 | 10:00 | 08/Jan/2025 | 12:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 139 | OCC_221 | AEGCL | 220KV-AGIA-BOKO-1 | AEGCL | D | CORRIDOR CLEANING | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 16:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 140 | OCC_221 | AEGCL | 132KV-SARUPATHAR-GOLAGHAT-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 15:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 141 | OCC_221 | AEGCL | 132KV-PARE-NORTH LAKHIMPUR-1 | NEEPCO,STERLITE | D | ROUTINE TESTING OF BAY EQUIPMENT | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 16:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 142 | OCC_221 | POWERGRID | 132KV-MELRIAT-SINHMUI-2 | POWERGRID | D | FOR AMP WORKS at Shimui end | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 17:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 143 | OCC_221 | POWERGRID | 400KV-BALIPARA-BONGAIGAON-4 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing location | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 17:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 144 | OCC_221 | POWERGRID | TRANSFER BUS COUPLER BAY (106) OF SALAKATI - 132KV - BUS 1 AND SALAKATI - 132KV - BUS 2 @SALAKATI - 132KV | POWERGRID | D | FOR BAY EQUIPMENT AMP WORK | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 17:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 145 | OCC_221 | POWERGRID | 400 KV BGTPP 2 BAY AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 08/Jan/2025 | 09:00 | 08/Jan/2025 | 13:00 | 05/Jan/2025 11:40 | 07/Jan/2025 12:19 | 48 Hours 39 Minutes |
| 146 | OCC_221 | NEEPCO | DOYANG - UNIT 3 | NEEPCO | C | Annual Planned Maintenance | 06/Jan/2025 | 00:00 | 30/Jan/2025 | 23:00 | 03/Jan/2025 08:38 | 05/Jan/2025 11:33 | 49 Hours 33 Minutes |
| 147 | OCC_221 | NEEPCO | RANGANADI - UNIT 1 | NEEPCO | C | Replacement of MIV seals and all other associated works of all 3 generating units, PLHPS | 07/Jan/2025 | 00:00 | 12/Mar/2025 | 23:00 | 04/Jan/2025 16:29 | 06/Jan/2025 11:42 | 43 Hours 13 Minutes |

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशु

चित्रांशु घांगरेकर (उप महाप्रबंधक)
Chitranshu Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|-----|---------|-----------|--|-----------------|---|---|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 148 | OCC_221 | NEEPCO | RANGANADI - UNIT 2 | NEEPCO | C | Replacement of MIV seals and all other associated works of all 3 generating units, PLHPS | 07/Jan/2025 | 00:00 | 12/Mar/2025 | 23:00 | 04/Jan/2025 16:29 | 06/Jan/2025 11:42 | 43 Hours 13 Minutes |
| 149 | OCC_221 | NEEPCO | RANGANADI - UNIT 3 | NEEPCO | C | Replacement of MIV seals and all other associated works of all 3 generating units, PLHPS | 07/Jan/2025 | 00:00 | 12/Mar/2025 | 23:00 | 04/Jan/2025 16:29 | 06/Jan/2025 11:42 | 43 Hours 13 Minutes |
| 150 | OCC_221 | POWERGRID | 400KV-MISA-MARIANI (PG)-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 07/Jan/2025 | 09:00 | 07/Jan/2025 | 17:00 | 04/Jan/2025 08:53 | 06/Jan/2025 11:42 | 49 Hours 42 Minutes |
| 151 | OCC_221 | MEPTCL | 220KV-BYRNHAT (KILLING)-MISA-1 | MEPTCL | D | For Lines maintenance works | 07/Jan/2025 | 08:00 | 07/Jan/2025 | 16:00 | 04/Jan/2025 01:05 | 06/Jan/2025 11:42 | 49 Hours 42 Minutes |
| 152 | OCC_221 | MEPTCL | 220KV-BYRNHAT (KILLING)-MISA-2 | MEPTCL | D | For Lines maintenance works | 07/Jan/2025 | 08:00 | 07/Jan/2025 | 16:00 | 04/Jan/2025 01:05 | 06/Jan/2025 11:42 | 49 Hours 42 Minutes |
| 153 | OCC_221 | AEGCL | 220KV/132KV AGIA-ICT-1 | AEGCL | D | ROUTINE TESTING | 07/Jan/2025 | 09:00 | 07/Jan/2025 | 16:00 | 04/Jan/2025 11:11 | 06/Jan/2025 11:42 | 48 Hours 31 Minutes |
| 154 | OCC_221 | POWERGRID | MAIN BAY (443) OF BISWANATH CHARIALI - 400KV B/R 1 @BISWANATH CHARIALI - 400KV | POWERGRID | D | AMP of bay equipment | 07/Jan/2025 | 09:00 | 07/Jan/2025 | 16:00 | 04/Jan/2025 08:53 | 06/Jan/2025 11:42 | 49 Hours 42 Minutes |
| 155 | OCC_221 | POWERGRID | TIE BAY (402) OF MARIANI (PG) - 400KV B/R 1 AND FUTURE @MARIANI (PG) - 400KV | POWERGRID | D | AMP of Bay equipments | 07/Jan/2025 | 09:00 | 07/Jan/2025 | 17:00 | 04/Jan/2025 08:53 | 06/Jan/2025 11:42 | 49 Hours 42 Minutes |
| 156 | OCC_221 | POWERGRID | 400 KV BYRNHAT BAY AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 07/Jan/2025 | 14:00 | 07/Jan/2025 | 17:00 | 04/Jan/2025 08:53 | 06/Jan/2025 11:42 | 49 Hours 42 Minutes |
| 157 | OCC_221 | AEGCL | 132KV-UMTRU-SARUSAJAI-1 | MEPTCL | D | PREVENTIVE MAINTENANCE OF BAY EQUIPMENT | 07/Jan/2025 | 10:00 | 07/Jan/2025 | 12:00 | 04/Jan/2025 11:11 | 06/Jan/2025 11:42 | 48 Hours 31 Minutes |
| 158 | OCC_221 | NEEPCO | AGTCCPP - STG 1 | NEEPCO | C | Inspection of STG #1 to resolve the issue of over speed during Start up. | 07/Jan/2025 | 10:00 | 08/Jan/2025 | 23:00 | 04/Jan/2025 20:51 | 06/Jan/2025 11:42 | 38 Hours 51 Minutes |
| 159 | OCC_221 | AEGCL | 220KV-BALIPARA-SONABIL-2 | AEGCL,POWERGRID | D | TESTING OF SWITCHYARD EQUIPMENT | 07/Jan/2025 | 09:00 | 07/Jan/2025 | 16:00 | 04/Jan/2025 11:11 | 06/Jan/2025 11:42 | 48 Hours 31 Minutes |
| 160 | OCC_221 | POWERGRID | 400KV-BALIPARA-BONGAIGAON-3 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing location | 07/Jan/2025 | 09:00 | 07/Jan/2025 | 17:00 | 04/Jan/2025 08:53 | 06/Jan/2025 11:42 | 49 Hours 42 Minutes |
| 161 | OCC_221 | AEGCL | 132KV-HAILAKANDI-DULLAVCHERRA-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK | 07/Jan/2025 | 09:00 | 07/Jan/2025 | 16:00 | 04/Jan/2025 11:11 | 06/Jan/2025 11:42 | 48 Hours 31 Minutes |
| 162 | OCC_221 | POWERGRID | 400 KV BALIPARA 3 BAY (WITH 63 MVAR LINE REACTOR) (418) AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 07/Jan/2025 | 09:00 | 07/Jan/2025 | 13:00 | 04/Jan/2025 08:53 | 06/Jan/2025 11:42 | 49 Hours 42 Minutes |

सहायक

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रंशी

चित्रंशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|-----|---------|-----------|--|-----------------|---|---|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 163 | OCC_221 | AEGCL | 220KV-MARIANI (AS)-AMGURI-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 07/Jan/2025 | 08:00 | 07/Jan/2025 | 16:00 | 04/Jan/2025 11:11 | 06/Jan/2025 11:42 | 48 Hours 31 Minutes |
| 164 | OCC_221 | POWERGRID | SURAJMANI NAGAR - 132KV - BUS 2 | TSECL | D | ISOALTOR ALIGNMENT RECTIFICATION WORKS WITH SD OF CO,LLA-2 FEDDER | 08/Jan/2025 | 10:00 | 08/Jan/2025 | 14:00 | 05/Jan/2025 09:50 | 06/Jan/2025 11:03 | 25 Hours 13 Minutes |
| 165 | OCC_221 | POWERGRID | 132KV-SURAJMANI NAGAR-COMILLA(BANGLADESH)-2 | PGCB,POWERGRID | D | FOR AMP WORKS AND ISOALTOR ALIGNMENT RECTIFICATION WORKS WITH BUS-II SD AT SM NAGAR | 08/Jan/2025 | 08:00 | 08/Jan/2025 | 16:00 | 05/Jan/2025 09:38 | 06/Jan/2025 11:03 | 25 Hours 25 Minutes |
| 166 | OCC_221 | POWERGRID | 400KV-MISA-MARIANI (PG)-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 06/Jan/2025 | 09:00 | 06/Jan/2025 | 17:00 | 03/Jan/2025 08:38 | 05/Jan/2025 11:33 | 49 Hours 33 Minutes |
| 167 | OCC_221 | POWERGRID | MAIN BAY (403) OF MARIANI (PG) - 400KV B/R 1 AND @MARIANI (PG) - 400KV | POWERGRID | D | AMP of Bay equipments | 06/Jan/2025 | 09:00 | 06/Jan/2025 | 17:00 | 03/Jan/2025 08:38 | 05/Jan/2025 11:33 | 49 Hours 33 Minutes |
| 168 | OCC_221 | POWERGRID | 400 KV ALIPURDUAR 2 BAY (416) AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 06/Jan/2025 | 14:00 | 06/Jan/2025 | 17:00 | 03/Jan/2025 08:38 | 05/Jan/2025 11:33 | 49 Hours 33 Minutes |
| 169 | OCC_221 | AEGCL | 132KV-BOKAJAN-DIMAPUR(PG) | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 06/Jan/2025 | 09:00 | 06/Jan/2025 | 16:00 | 03/Jan/2025 10:57 | 05/Jan/2025 11:33 | 48 Hours 36 Minutes |
| 170 | OCC_221 | AEGCL | 220KV-BALIPARA-SONABIL-1 | AEGCL,POWERGRID | D | TESTING OF SWITCHYARD EQUIPMENT | 06/Jan/2025 | 09:00 | 06/Jan/2025 | 16:00 | 03/Jan/2025 10:57 | 05/Jan/2025 11:33 | 48 Hours 36 Minutes |
| 171 | OCC_221 | POWERGRID | 132KV-MELRIAT-SINHMUI-1 | POWERGRID | D | FOR AMP WORKS at Shimui end | 06/Jan/2025 | 09:00 | 06/Jan/2025 | 17:00 | 03/Jan/2025 08:38 | 05/Jan/2025 11:33 | 49 Hours 33 Minutes |
| 172 | OCC_221 | POWERGRID | 400 KV MISA 1 MAIN BAY (410) AT BALIPARA | POWERGRID | D | AMP works | 06/Jan/2025 | 09:00 | 06/Jan/2025 | 17:00 | 03/Jan/2025 08:38 | 05/Jan/2025 11:33 | 49 Hours 33 Minutes |
| 173 | OCC_221 | AEGCL | 132KV-HAILAKANDI-PANCHGRAM (NEW)-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK | 06/Jan/2025 | 09:00 | 06/Jan/2025 | 16:00 | 03/Jan/2025 10:57 | 05/Jan/2025 11:33 | 48 Hours 36 Minutes |
| 174 | OCC_221 | POWERGRID | 400 KV BALIPARA 1 BAY(WITH 63 MVAR LINE REACTOR) (413) AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 06/Jan/2025 | 09:00 | 06/Jan/2025 | 13:00 | 03/Jan/2025 08:38 | 05/Jan/2025 11:33 | 49 Hours 33 Minutes |
| 175 | OCC_221 | POWERGRID | 132KV-AGTCCPP-KUMARGHAT-1 | POWERGRID | C | For de-stringing of the section from loc. 236 to 237 to 238 and then to stringing through ERS from 236 to 238 for facilitating the permanent restoration of vulnerable tower 237 on account of land slide located at hill top and railway crossing was below. | 06/Jan/2025 | 08:00 | 13/Jan/2025 | 16:00 | 03/Jan/2025 08:38 | 05/Jan/2025 11:33 | 49 Hours 33 Minutes |
| 176 | OCC_221 | AEGCL | 220KV-BTPS-RANGIA-2 | AEGCL | C | stringing of Single Conductor (Circuit 2) between the tower 450-451 and 451-452 along with Dismantling of existing conductor | 06/Jan/2025 | 07:00 | 08/Jan/2025 | 17:00 | 03/Jan/2025 08:38 | 05/Jan/2025 11:33 | 49 Hours 33 Minutes |
| 177 | OCC_221 | POWERGRID | 400KV-MISA-MARIANI (PG)-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 04/Jan/2025 | 09:00 | 04/Jan/2025 | 17:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitrankshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|-----|---------|-----------|--|--------------------------|---|---|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 178 | OCC_221 | AEGCL | 220KV-AGIA-BTPS-2 | AEGCL | D | CORRIDOR CLEANING | 04/Jan/2025 | 08:00 | 04/Jan/2025 | 16:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 179 | OCC_221 | AEGCL | SRIKONA - 132KV - BUS 1 | AEGCL | D | MAINTENANCE OF 132KV BUS | 05/Jan/2025 | 07:00 | 05/Jan/2025 | 10:00 | 02/Jan/2025 10:07 | 04/Jan/2025 10:52 | 48 Hours 45 Minutes |
| 180 | OCC_221 | POWERGRID | 400 KV, 50 MVAR BUS REACTOR 2 BAY AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 04/Jan/2025 | 14:00 | 04/Jan/2025 | 17:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 181 | OCC_221 | AEGCL | 132KV-RUPAI-MARGHERITA_AS-1 | AEGCL | D | DOUBLE JUMPERING WORK AT LOC 54 | 04/Jan/2025 | 11:30 | 04/Jan/2025 | 15:30 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 182 | OCC_221 | POWERGRID | 132KV-SILCHAR-SRIKONA-2 | POWERGRID | D | Replacement of existing static LBB relay with numerical LBB relay | 04/Jan/2025 | 09:00 | 04/Jan/2025 | 17:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 183 | OCC_221 | POWERGRID | 400 KV NEW SILIGURI 2 BAY(WITH 63 MVAR LINE REACTOR) (407) AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 04/Jan/2025 | 09:00 | 04/Jan/2025 | 13:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 184 | OCC_221 | POWERGRID | MAIN (2) BAY OF 400KV-BALIPARA-MISA-1 @MISA - 400KV | POWERGRID | D | AMP of Bay equipments | 04/Jan/2025 | 09:00 | 04/Jan/2025 | 17:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 185 | OCC_221 | NAGALAND | 132KV-DOYANG-MOKOKCHUNG-1 | NAGALAND,DOP | D | Relay testing, CT primary injection test. | 04/Jan/2025 | 09:00 | 04/Jan/2025 | 15:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 186 | OCC_221 | AEGCL | 220KV-SAMAGURI-SONABIL-2 | AEGCL | D | TESTING OF SWITCHYARD EQUIPMENT AT SONABIL END & CORRIDIOR CLEANING | 04/Jan/2025 | 08:00 | 04/Jan/2025 | 16:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 187 | OCC_221 | POWERGRID | 132KV-AIZWAL-KOLASIB-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 04/Jan/2025 | 08:00 | 04/Jan/2025 | 16:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 188 | OCC_221 | AEGCL | 132KV-TINSUKIA-MARGHERITA_AS-1 | AEGCL | D | DOUBLE JUMPERING WORK AT LOC 54 | 04/Jan/2025 | 07:00 | 04/Jan/2025 | 11:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 189 | OCC_221 | AEGCL | 132KV-GOHPUR-NALKATA-2 | POWERGRID | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 04/Jan/2025 | 07:00 | 04/Jan/2025 | 14:00 | 01/Jan/2025 14:18 | 03/Jan/2025 12:11 | 45 Hours 53 Minutes |
| 190 | OCC_221 | NEEPCO | 132KV-PARE-ITANAGAR-1 | NEEPCO,ARUNACHAL PRADESH | D | Vegetation Clearance in LILOPortion of 132KV Pare-Itanagar and 132KV Pare-Ranganadi (PLHPS) Line | 04/Jan/2025 | 06:00 | 04/Jan/2025 | 14:00 | 01/Jan/2025 10:53 | 03/Jan/2025 12:11 | 49 Hours 18 Minutes |
| 191 | OCC_221 | NEEPCO | 132KV-RANGANADI-PARE-1 | POWERGRID | D | Vegetation Clearance in LILOPortion of 132KV Pare-Itanagar and 132KV Pare-Ranganadi (PLHPS) Line | 04/Jan/2025 | 06:00 | 04/Jan/2025 | 14:00 | 01/Jan/2025 10:53 | 03/Jan/2025 12:11 | 49 Hours 18 Minutes |
| 192 | OCC_221 | POWERGRID | 400KV-MISA-MARIANI (PG)-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 03/Jan/2025 | 09:00 | 03/Jan/2025 | 17:00 | 31/Dec/2024 10:34 | 02/Jan/2025 11:18 | 48 Hours 44 Minutes |
| 193 | OCC_221 | AEGCL | 220KV/132KV AGIA-ICT-3 | AEGCL | D | ROUTINE TESTING | 03/Jan/2025 | 09:00 | 03/Jan/2025 | 16:00 | 01/Jan/2025 12:53 | 02/Jan/2025 11:18 | 22 Hours 25 Minutes |
| 194 | OCC_221 | POWERGRID | MAIN BAY () OF 400KV/220KV BONGAIGAON-ICT-1 @BONGAIGAON - 400KV | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 03/Jan/2025 | 14:00 | 03/Jan/2025 | 17:00 | 31/Dec/2024 10:34 | 02/Jan/2025 11:18 | 48 Hours 44 Minutes |
| 195 | OCC_221 | AEGCL | 132KV-GOLAGHAT-MARIANI (AS)-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 03/Jan/2025 | 09:00 | 03/Jan/2025 | 15:00 | 31/Dec/2024 12:03 | 02/Jan/2025 11:18 | 47 Hours 15 Minutes |
| 196 | OCC_221 | POWERGRID | 400 KV BONGAIGAON 3 MAIN BAY(WITH 63 MVAR LINE REACTOR) (419) AT BALIPARA | POWERGRID | D | AMP works | 03/Jan/2025 | 09:00 | 03/Jan/2025 | 17:00 | 31/Dec/2024 10:34 | 02/Jan/2025 11:18 | 48 Hours 44 Minutes |
| 197 | OCC_221 | POWERGRID | 400 KV, 125 MVAR BUS REACTOR 5 BAY AT BONGAIGAON | POWERGRID | D | AC & DC wiring of new Busbar in CT JB and CRP Panel. | 03/Jan/2025 | 09:00 | 03/Jan/2025 | 13:00 | 31/Dec/2024 10:34 | 02/Jan/2025 11:18 | 48 Hours 44 Minutes |
| 198 | OCC_221 | AEGCL | 132KV-SRIKONA-PAILAPPOL-1 | AEGCL | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK | 03/Jan/2025 | 09:00 | 03/Jan/2025 | 16:00 | 31/Dec/2024 12:03 | 02/Jan/2025 11:18 | 47 Hours 15 Minutes |
| 199 | OCC_221 | POWERGRID | 400 KV, 200 MVA ICT 1 MAIN BAY AT SILCHAR | POWERGRID | D | •AMP of Bay equipment •DB DCRM, CRM, Timing Testing, CT Tandelta testing •Cleaning & Tightening works | 03/Jan/2025 | 09:00 | 03/Jan/2025 | 17:00 | 31/Dec/2024 10:34 | 02/Jan/2025 11:18 | 48 Hours 44 Minutes |

सक्षम

सक्षम रीठे (सहायक प्रबंधक)
Saksham Rithe (Assistant Manager)

चित्रांशी

चित्रांशी घांगरेकर (उप महाप्रबंधक)
Chitranshi Ghangrekar (Dy. General Manager)

| | | | | | | | | | | | | | |
|---|---------|-----------|---|--------------------------|---|---|-------------|-------|-------------|-------|-------------------|-------------------|---------------------|
| 200 | OCC_221 | AEGCL | 220KV-AZARA-BOKO-1 | AEGCL | D | CORRIDOR CLEANING | 03/Jan/2025 | 08:00 | 03/Jan/2025 | 16:00 | 31/Dec/2024 12:03 | 02/Jan/2025 11:18 | 47 Hours 15 Minutes |
| 201 | OCC_221 | AEGCL | 132KV-GOHPUR-NALKATA-1 | POWERGRID | D | PREVENTIVE MAINTENANCE & CORRIDOR CLEANING | 03/Jan/2025 | 07:00 | 03/Jan/2025 | 14:00 | 31/Dec/2024 12:03 | 02/Jan/2025 11:18 | 47 Hours 15 Minutes |
| 202 | OCC_221 | NEEPCO | 132KV-PARE-ITANAGAR-1 | NEEPCO,ARUNACHAL PRADESH | D | Vegetation Clearance in LIOPortion of 132kv Pare-Itanagar and 132kv Pare-Ranganadi (PLHPS) Line | 03/Jan/2025 | 06:00 | 03/Jan/2025 | 14:00 | 31/Dec/2024 16:31 | 02/Jan/2025 11:18 | 42 Hours 47 Minutes |
| 203 | OCC_221 | NEEPCO | 132KV-RANGANADI-PARE-1 | POWERGRID | D | Vegetation Clearance in LIOPortion of 132kv Pare-Itanagar and 132kv Pare-Ranganadi (PLHPS) Line | 03/Jan/2025 | 06:00 | 03/Jan/2025 | 14:00 | 31/Dec/2024 16:31 | 02/Jan/2025 11:18 | 42 Hours 47 Minutes |
| 204 | OCC_221 | AEGCL | 220KV-AGIA-BTPS-1 | AEGCL | D | CORRIDOR CLEANING | 02/Jan/2025 | 08:00 | 02/Jan/2025 | 16:00 | 30/Dec/2024 12:15 | 01/Jan/2025 11:28 | 47 Hours 13 Minutes |
| 205 | OCC_221 | POWERGRID | TIE BAY (426) OF 400KV-MISA-MARIANI (PG)-1 AND 400KV/220KV MISA-ICT-2 @MISA - 400KV | POWERGRID | D | AMP of Bay equipments | 02/Jan/2025 | 09:00 | 02/Jan/2025 | 17:00 | 30/Dec/2024 12:15 | 01/Jan/2025 11:28 | 47 Hours 13 Minutes |
| 206 | OCC_221 | POWERGRID | 400KV-MISA-MARIANI (PG)-1 | POWERGRID | D | For replacement of conventional porcelain insulators by composite long rod polymer insulators at Power/Deep valley/River/SH/NH crossing locations | 02/Jan/2025 | 09:00 | 02/Jan/2025 | 17:00 | 30/Dec/2024 12:15 | 01/Jan/2025 11:28 | 47 Hours 13 Minutes |
| 207 | OCC_221 | AEGCL | 220KV-JAWAHARNAGAR-SAMAGURI-1 | AEGCL | D | CORRIDOR CLEANING | 02/Jan/2025 | 07:00 | 02/Jan/2025 | 16:00 | 30/Dec/2024 10:45 | 01/Jan/2025 11:28 | 48 Hours 43 Minutes |
| 208 | OCC_221 | NEEPCO | 132KV-PARE-ITANAGAR-1 | NEEPCO,ARUNACHAL PRADESH | D | Vegetation Clearance in LIOPortion of 132kv Pare-Itanagar and 132kv Pare-Ranganadi (PLHPS) Line | 02/Jan/2025 | 06:00 | 02/Jan/2025 | 14:00 | 30/Dec/2024 11:18 | 01/Jan/2025 11:28 | 48 Hours 10 Minutes |
| 209 | OCC_221 | NEEPCO | 132KV-RANGANADI-PARE-1 | POWERGRID | D | Vegetation Clearance in LIOPortion of 132kv Pare-Itanagar and 132kv Pare-Ranganadi (PLHPS) Line | 02/Jan/2025 | 06:00 | 02/Jan/2025 | 14:00 | 30/Dec/2024 11:18 | 01/Jan/2025 11:28 | 48 Hours 10 Minutes |
| 210 | OCC_221 | NEEPCO | KOPLII - UNIT 3 | NEEPCO | C | Annual Planned Maintenance | 02/Jan/2025 | 00:00 | 16/Jan/2025 | 23:00 | 30/Dec/2024 11:18 | 01/Jan/2025 11:28 | 48 Hours 10 Minutes |
| <div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: center;"> <p><u>सक्षम</u></p> <p>सक्षम रीठे (सहायक प्रबंधक) Saksham Rithe (Assistant Manager)</p> </div> <div style="text-align: center;"> <p><u>चित्री</u></p> <p>चित्रींशी घांगरेकर (उप महाप्रबंधक) Chitranksi Ghangrekar (Dy. General Manager)</p> </div> </div> | | | | | | | | | | | | | |