

**OCC Approved Shutdowns for the month of May'24**

Sl. No.	OCC Number	Name of Requesting Agency	Element Name	Owner	Daily/Continuous	Reason	RLDC Approved Start Date	RLDC Approved Start Time	RLDC Approved End Date	RLDC Approved End Time	D-3 Confirmation Date and Time	RLDC Processed Time	Shutdown Co-ordination Process Time
1	OCC_213	NAGALAND	132KV-KOHIMA-MELURI-1	NAGALAND	D	Vegetation Clearance	31/May/2024	08:00	31/May/2024	15:00	28/May/2024 10:53	30/May/2024 12:19	49 Hours 19 Minutes
2	OCC_213	AEGCL	220KV-JAWAHARNAGAR-SAMAGURI-1	AEGCL	D	CORRIDOR CLEANING	31/May/2024	07:00	31/May/2024	15:00	28/May/2024 11:03	30/May/2024 12:19	49 Hours 16 Minutes
3	OCC_213	AEGCL	220KV-BTPS-RANGIA-1	AEGCL	D	CORRIDOR CLEANING	30/May/2024	08:00	30/May/2024	16:00	27/May/2024 08:36	29/May/2024 10:09	48 Hours 9 Minutes
4	OCC_213	AEGCL	220KV-BTPS-RANGIA-2	AEGCL	D	CORRIDOR CLEANING	29/May/2024	08:00	29/May/2024	16:00	26/May/2024 11:36	29/May/2024 10:23	48 Hours 23 Minutes
5	OCC_213	POWERGRID	400KV-SILCHAR-IMPHAL(PG)-1	POWERGRID	D	For replacement of conventional porcelain insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	30/May/2024	08:00	30/May/2024	17:00	27/May/2024 08:36	29/May/2024 10:09	48 Hours 9 Minutes
6	OCC_213	AEGCL	220KV-TINSUKIA-NTPS-1	ASSAM	D	PREVENTIVE MAINTENANCE & CORRADOR CLEANING WORK	30/May/2024	09:00	30/May/2024	16:00	27/May/2024 11:23	29/May/2024 10:09	46 Hours 46 Minutes
7	OCC_213	AEGCL	220KV-AGIA-AZARA-1	AEGCL	D	CORRIDOR CLEANING	30/May/2024	09:00	30/May/2024	16:00	27/May/2024 11:23	29/May/2024 10:09	46 Hours 46 Minutes
8	OCC_213	NAGALAND	132KV-KOHIMA-MELURI-1	NAGALAND	D	Vegetation Clearance	30/May/2024	08:00	30/May/2024	15:00	26/May/2024 09:05	28/May/2024 11:12	49 Hours 12 Minutes
9	OCC_213	AEGCL	220KV-AZARA-BOKO-1	AEGCL	D	CORRIDOR CLEANING	29/May/2024	09:00	29/May/2024	16:00	24/May/2024 11:17	26/May/2024 10:17	47 Hours 0 Minutes
10	OCC_213	NAGALAND	132KV-DIMAPUR(PG)-KOHIMA-1	NAGALAND	D	Vegetation Clearance	31/May/2024	08:00	31/May/2024	15:00	28/May/2024 11:03	30/May/2024 12:19	49 Hours 16 Minutes
11	OCC_213	POWERGRID	400KV-SILCHAR-IMPHAL(PG)-1	POWERGRID	D	For replacement of conventional porcelain insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	29/May/2024	08:00	29/May/2024	17:00	26/May/2024 09:05	28/May/2024 11:12	49 Hours 12 Minutes
12	OCC_213	NAGALAND	132KV-KOHIMA-MELURI-1	NAGALAND	D	Vegetation Clearance	29/May/2024	08:00	29/May/2024	15:00	26/May/2024 08:10	28/May/2024 11:12	49 Hours 12 Minutes
13	OCC_213	AEGCL	220KV-AGIA-BOKO-1	AEGCL	D	CORRIDOR CLEANING	31/May/2024	09:00	31/May/2024	16:00	28/May/2024 11:03	30/May/2024 12:19	49 Hours 16 Minutes
14	OCC_213	POWERGRID	TIE BAY (I) OF 400KV/220KV BALIPARA-ICT-1 AND BALIPARA - 400KV B/R 1 @BALIPARA - 400KV	POWERGRID	C	LBB RELAY REPLACEMENT WORKS	28/May/2024	09:00	29/May/2024	17:00	25/May/2024 10:51	27/May/2024 10:23	47 Hours 32 Minutes

*Saksham*



Saksham Rithe (Assistant Manager)



*चित्रांशी*

Chitranksi Ghangrekar Dy. General Manager


15	OCC_213	POWERGRID	400KV-SILCHAR-IMPHAL(PG)-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer Insulators at Power/Deep valley/River/SH/NH Crossing locations	28/May/2024	08:00	28/May/2024	17:00	25/May/2024 10:51	27/May/2024 10:23	47 Hours 32 Minutes
16	OCC_213	POWERGRID	400KV-SILCHAR-MISA-1	INDIGRID	D	CT ratio changing for the metering circuit. Refilling of gas at 429 R-phase CT.	30/May/2024	09:00	30/May/2024	16:00	27/May/2024 11:23	29/May/2024 10:09	46 Hours 46 Minutes
17	OCC_213	NAGALAND	132KV-DIMAPUR(PG)-KOHIMA-1	NAGALAND	D	Vegetation Clearance	30/May/2024	08:00	30/May/2024	15:00	27/May/2024 11:23	29/May/2024 10:09	46 Hours 46 Minutes
18	OCC_213	NAGALAND	132KV-DIMAPUR(PG)-KOHIMA-1	NAGALAND	D	Vegetation Clearance	29/May/2024	08:00	29/May/2024	15:00	23/May/2024 10:57	25/May/2024 11:34	48 Hours 37 Minutes
19	OCC_213	POWERGRID	400KV-SILCHAR-IMPHAL(PG)-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	26/May/2024	08:00	26/May/2024	17:00	23/May/2024 08:40	25/May/2024 11:34	49 Hours 34 Minutes
20	OCC_213	POWERGRID	132KV-BADARPUR-KARIMGANJ (A5)-1	POWERGRID	D	AMP of Bay equipments	25/May/2024	08:00	25/May/2024	16:00	22/May/2024 08:48	24/May/2024 11:08	49 Hours 8 Minutes
21	OCC_213	POWERGRID	400KV-SILCHAR-IMPHAL(PG)-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	25/May/2024	08:00	25/May/2024	17:00	22/May/2024 08:48	24/May/2024 11:08	49 Hours 8 Minutes
22	OCC_213	NAGALAND	132KV-DOYANG-MOKOKCHUNG-1	NAGALAND	D	Vegetation Clearance	25/May/2024	08:00	25/May/2024	15:00	22/May/2024 14:07	24/May/2024 11:08	45 Hours 1 Minutes
23	OCC_213	NAGALAND	132KV-DIMAPUR(PG)-KOHIMA-1	NAGALAND	D	Vegetation Clearance	25/May/2024	08:00	25/May/2024	15:00	22/May/2024 14:07	24/May/2024 11:08	45 Hours 1 Minutes
24	OCC_213	NAGALAND	132KV-KOHIMA-KARONG-1	NAGALAND	D	Vegetation Clearance	24/May/2024	08:00	24/May/2024	15:00	21/May/2024 10:04	23/May/2024 09:20	47 Hours 16 Minutes
25	OCC_213	POWERGRID	MAIN BAY (205) OF 400KV/220KV BALIPARA-ICT-2 @BALIPARA - 220KV	POWERGRID	D	AMP WORKS	24/May/2024	09:00	24/May/2024	17:00	21/May/2024 08:20	23/May/2024 09:20	47 Hours 20 Minutes
26	OCC_213	POWERGRID	132KV-DIMAPUR(PG)-DOYANG-2	POWERGRID	D	Replacement of Porcelain Insulator Strings having lightning marks and jumper tightening works	24/May/2024	08:00	24/May/2024	16:00	21/May/2024 08:20	23/May/2024 09:20	47 Hours 20 Minutes
27	OCC_213	POWERGRID	400KV-SILCHAR-IMPHAL(PG)-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	24/May/2024	08:00	24/May/2024	17:00	21/May/2024 08:20	23/May/2024 09:20	47 Hours 20 Minutes
28	OCC_213	TSECL	132KV-PK BARI (STERLITE)-AMBASA-1	TSECL,INDIA	D	Routine Maintenance	24/May/2024	09:00	24/May/2024	16:00	21/May/2024 09:16	23/May/2024 09:20	47 Hours 20 Minutes
29	OCC_213	NAGALAND	132KV-DOYANG-MOKOKCHUNG-1	NAGALAND	D	Vegetation Clearance	24/May/2024	08:00	24/May/2024	15:00	21/May/2024 10:04	23/May/2024 09:20	47 Hours 16 Minutes
30	OCC_213	NAGALAND	132KV-KOHIMA-KARONG-1	NAGALAND	D	Vegetation Clearance	23/May/2024	08:00	23/May/2024	15:00	20/May/2024 11:41	22/May/2024 10:04	46 Hours 23 Minutes
31	OCC_213	POWERGRID	400KV-BYRNHAT (KILLING)-SILCHAR	MEPTCL,INDIA	D	Checking AR for both main & Tie Bay	23/May/2024	09:00	23/May/2024	17:00	20/May/2024 09:05	22/May/2024 10:04	48 Hours 4 Minutes
<div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: center;">   Saksham Rithe (Assistant Manager) </div> <div style="text-align: center;">   Chitranshi Ghangrekar Dy. General Manager) </div> </div>													

32	OCC_213	POWERGRID	132KV-DIMAPUR(PG)-DOYANG-2	POWERGRID	D	Replacement of Porcelain Insulator Strings having lightning marks and jumper tightening works	23/May/2024	08:00	23/May/2024	16:00	20/May/2024 09:05	22/May/2024 10:04	48 Hours 4 Minutes
33	OCC_213	POWERGRID	400KV-SILCHAR-IMPHAL(PG)-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	23/May/2024	08:00	23/May/2024	17:00	20/May/2024 09:05	22/May/2024 10:04	48 Hours 4 Minutes
34	OCC_213	TSECL	132KV-PK BARI (STERLITE)-AMBASA-1	TSECL	INDIA	Routine Maintenance	23/May/2024	09:00	23/May/2024	16:00	20/May/2024 09:46	22/May/2024 10:04	48 Hours 4 Minutes
35	OCC_213	NAGALAND	132KV-DOYANG-MOKOKCHUNG-1	NAGALAND	D	Vegetation Clearance	23/May/2024	08:00	23/May/2024	15:00	20/May/2024 11:41	22/May/2024 10:04	46 Hours 23 Minutes
36	OCC_213	NAGALAND	132KV-KOHIMA-KARONG-1	NAGALAND	D	Vegetation Clearance	22/May/2024	08:00	22/May/2024	15:00	19/May/2024 11:40	21/May/2024 10:45	47 Hours 5 Minutes
37	OCC_213	POWERGRID	MAIN BAY (202) OF 400KV/220KV BALIPARA-ICT-1 @BALIPARA - 220KV	POWERGRID	D	AMP works	22/May/2024	09:00	22/May/2024	17:00	19/May/2024 08:34	21/May/2024 10:45	48 Hours 45 Minutes
38	OCC_213	POWERGRID	132KV-DIMAPUR(PG)-DOYANG-1	POWERGRID	D	Replacement of Porcelain Insulator Strings having lightning marks and jumper tightening works	22/May/2024	08:00	22/May/2024	16:00	19/May/2024 08:34	21/May/2024 10:45	48 Hours 45 Minutes
39	OCC_213	AEGCL	220KV-TINSUKIA-NRPP-1	ASSAM	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	22/May/2024	09:00	22/May/2024	16:00	19/May/2024 10:43	21/May/2024 10:45	48 Hours 2 Minutes
40	OCC_213	AEGCL	220KV-JAWAHARNAGAR-SARUSAJAI-1	AEGCL	D	CORRIDOR CLEANING	22/May/2024	08:00	22/May/2024	16:00	19/May/2024 10:43	21/May/2024 10:45	48 Hours 2 Minutes
41	OCC_213	NAGALAND	132KV-DOYANG-MOKOKCHUNG-1	NAGALAND	D	Vegetation Clearance	22/May/2024	08:00	22/May/2024	15:00	19/May/2024 11:40	21/May/2024 10:45	47 Hours 5 Minutes
42	OCC_213	NAGALAND	132KV-KOHIMA-KARONG-1	NAGALAND	D	Vegetation Clearance	21/May/2024	08:00	21/May/2024	15:00	18/May/2024 10:20	20/May/2024 11:40	49 Hours 20 Minutes
43	OCC_213	POWERGRID	BONGAIGAON - 400KV BUS 1	POWERGRID	D	For replacement of existing bus bar protection and sectionalization of Bus Bar.	21/May/2024	09:00	21/May/2024	16:00	18/May/2024 11:24	20/May/2024 11:40	48 Hours 14 Minutes
44	OCC_213	POWERGRID	132KV-SILCHAR-MELRIAT-1	POWERGRID	D	AMP of Bay Equipment	21/May/2024	09:00	21/May/2024	16:00	18/May/2024 11:22	20/May/2024 11:40	48 Hours 18 Minutes
45	OCC_213	POWERGRID	132KV-DIMAPUR(PG)-DOYANG-1	POWERGRID	D	Replacement of Porcelain insulator Strings having lightning marks and jumper tightening works	21/May/2024	08:00	21/May/2024	16:00	18/May/2024 11:22	20/May/2024 11:40	48 Hours 18 Minutes
46	OCC_213	AEGCL	220KV-AGIA-BTPS-2	AEGCL	D	CORRIDOR CLEANING	21/May/2024	09:00	21/May/2024	16:00	18/May/2024 11:34	20/May/2024 11:40	48 Hours 06 Minutes
47	OCC_213	TSECL	132KV-P K BARI-PK BARI (STERLITE)-1	INDIGRID	D	Routine Maintenance	21/May/2024	09:00	21/May/2024	16:00	18/May/2024 11:34	20/May/2024 11:40	48 Hours 06 Minutes
48	OCC_213	AEGCL	220KV-MARIANI (AS)-SAMAGURI-2	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	21/May/2024	08:00	21/May/2024	16:00	18/May/2024 11:34	20/May/2024 11:40	48 Hours 06 Minutes
49	OCC_213	NAGALAND	132KV-DOYANG-MOKOKCHUNG-1	NAGALAND	D	Vegetation Clearance	21/May/2024	08:00	21/May/2024	15:00	18/May/2024 11:34	20/May/2024 11:40	48 Hours 06 Minutes
50	OCC_213	NAGALAND	132KV-KOHIMA-KARONG-1	NAGALAND	D	Vegetation Clearance	20/May/2024	08:00	20/May/2024	15:00	17/May/2024 13:19	19/May/2024 11:13	45 Hours 54 Minutes
 Saksham Rithe (Assistant Manager)													 Chitranshi Ghangrekar Dy. General Manager

51	OCC_213	POWERGRID	BONGAIGAON - 400KV BUS 1	POWERGRID	D	For replacement of existing bus bar protection and sectionalization of Bus Bar.	20/May/2024	09:00	20/May/2024	16:00	17/May/2024 11:27	19/May/2024 11:13	47 Hours 46 Minutes												
52	OCC_213	POWERGRID	400KV-BALIPARA-BONGAIGAON-1 L/R@BALIPARA - 400KV	POWERGRID	D	AMP works	20/May/2024	09:00	20/May/2024	17:00	17/May/2024 10:49	19/May/2024 11:13	48 Hours 24 Minutes												
53	OCC_213	POWERGRID	132KV-BADARPUR-KHUIEHRIAT-1	POWERGRID	C	For Reconductoring of existing single AAAC Panther with single HTLS conductor.	20/May/2024	08:00	31/May/2024	17:00	17/May/2024 10:49	19/May/2024 11:13	48 Hours 24 Minutes												
54	OCC_213	TSECL	132KV-P K BARI-PK BARI (STERLITE)-1	INDIGRID	D	Routine Maintenance	20/May/2024	09:00	20/May/2024	16:00	17/May/2024 10:45	19/May/2024 11:13	48 Hours 28 Minutes												
55	OCC_213	AEGCL	220KV-AGIA-BTPS-1	AEGCL	D	CORRIDOR CLEANING	20/May/2024	09:00	20/May/2024	16:00	17/May/2024 11:48	19/May/2024 11:13	47 Hours 25 Minutes												
56	OCC_213	AEGCL	220KV-MARIANI (AS)-SAMAGURI-2	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	20/May/2024	08:00	20/May/2024	16:00	17/May/2024 11:48	19/May/2024 11:13	47 Hours 25 Minutes												
57	OCC_213	NAGALAND	132KV-DOYANG-MOKOKCHUNG-1	NAGALAND	D	Vegetation Clearance	20/May/2024	08:00	20/May/2024	15:00	17/May/2024 13:19	19/May/2024 11:13	45 Hours 54 Minutes												
58	OCC_213	POWERGRID	132KV-SILCHAR-HAILAKANDI-2	POWERGRID	D	AMP of Bay equipments	18/May/2024	08:00	18/May/2024	16:00	15/May/2024 08:53	17/May/2024 10:25	48 Hours 25 Minutes												
59	OCC_213	AEGCL	220KV-SAMAGURI-SONABIL-2	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	18/May/2024	08:00	18/May/2024	16:00	15/May/2024 10:07	17/May/2024 10:25	48 Hours 18 Minutes												
60	OCC_213	POWERGRID	400KV-BONGAIGAON-BYRNHAT (KILLING)	MEPTCL	D	AMP of Line Reactor.	17/May/2024	09:00	17/May/2024	17:00	14/May/2024 11:03	16/May/2024 10:56	47 Hours 53 Minutes												
61	OCC_213	POWERGRID	220KV-MISA-KOPILI-3	POWERGRID	D	AMP of Bay equipments at Misa S/S	17/May/2024	08:00	17/May/2024	16:00	14/May/2024 11:03	16/May/2024 10:56	47 Hours 53 Minutes												
62	OCC_213	AEGCL	132KV-SARUPATHAR-BOKAJAN-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	17/May/2024	09:00	17/May/2024	16:00	14/May/2024 11:03	16/May/2024 10:56	47 Hours 53 Minutes												
63	OCC_213	TSECL	132KV-AMBASA-GAMATILLA-1	TSECL	D	Routine Maintenance	17/May/2024	09:00	17/May/2024	16:00	14/May/2024 14:27	16/May/2024 10:56	44 Hours 29 Minutes												
64	OCC_213	AEGCL	220KV-SAMAGURI-SONABIL-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	17/May/2024	08:00	17/May/2024	16:00	14/May/2024 11:03	16/May/2024 10:56	47 Hours 53 Minutes												
65	OCC_213	AEGCL	220KV-BTPS-RANGIA-1	AEGCL	D	CORRIDOR CLEANING	16/May/2024	08:00	16/May/2024	16:00	13/May/2024 10:38	15/May/2024 11:07	48 Hours 29 Minutes												
66	OCC_213	AEGCL	220KV-AGBPP-TINSUKIA-2	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	16/May/2024	09:00	16/May/2024	16:00	13/May/2024 10:38	15/May/2024 11:07	48 Hours 29 Minutes												
67	OCC_213	AEGCL	132KV-GOHPUR-PAVOI-1	AEGCL	D	CORRIDOR CLEANING AT LOCATION 211-212 & 330-331 . BOTH CKTS REQUIRED TOGETHER	16/May/2024	09:00	16/May/2024	13:00	13/May/2024 10:38	15/May/2024 11:07	48 Hours 29 Minutes												
68	OCC_213	AEGCL	132KV-GOHPUR-PAVOI-2	AEGCL	D	CORRIDOR CLEANING AT LOCATION 211-212 & 330-331 . BOTH CKTS REQUIRED TOGETHER	16/May/2024	09:00	16/May/2024	13:00	13/May/2024 10:38	15/May/2024 11:07	48 Hours 29 Minutes												
69	OCC_213	TSECL	132KV-AMBASA-GAMATILLA-1	TSECL	D	Routine Maintenance	16/May/2024	09:00	16/May/2024	16:00	13/May/2024 09:40	15/May/2024 11:07	49 Hours 7 Minutes												
70	OCC_213	AEGCL	220KV-JAWAHARNAGAR-SAMAGURI-1	AEGCL	D	CORRIDOR CLEANING	16/May/2024	08:00	16/May/2024	16:00	13/May/2024 10:38	15/May/2024 11:07	48 Hours 29 Minutes												
71	OCC_213	AEGCL	220KV-AGIA-BTPS-1	AEGCL	D	CORRIDOR CLEANING	15/May/2024	09:00	15/May/2024	16:00	12/May/2024 10:28	14/May/2024 11:37	49 Hours 9 Minutes												
72	OCC_213	AEGCL	132KV-BOKAJAN-DIMAPUR(PG)	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	15/May/2024	09:00	15/May/2024	16:00	12/May/2024 10:28	14/May/2024 11:37	49 Hours 9 Minutes												
 Saksham Rithe (Assistant Manager)													 Chitranshi Ghangrekar Dy. General Manager												

73	OCC 213	AEGCL	220KV-BTPS-RANGIA-2	AEGCL	D	CORRIDOR CLEANING	15/May/2024	08:00	15/May/2024	16:00	12/May/2024 10:28	14/May/2024 11:37	49 Hours 9 Minutes
74	OCC 213	AEGCL	220KV-JAWAHARNAGAR-SAMAGURI-1	AEGCL	D	CORRIDOR CLEANING	15/May/2024	08:00	15/May/2024	16:00	12/May/2024 10:28	14/May/2024 11:37	49 Hours 9 Minutes
75	OCC 213	AEGCL	132KV-DHARMANAGAR (MISSION TILLA)-DULLAVCHERRA-1	AEGCL	TSE	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	15/May/2024	08:00	15/May/2024	16:00	12/May/2024 10:28	14/May/2024 11:37	49 Hours 9 Minutes
76	OCC 213	AEGCL	AZARA - 400KV B/R 1	AEGCL	C	OIL FILTRATION WORK	14/May/2024	08:00	16/May/2024	17:00	11/May/2024 13:37	13/May/2024 13:05	47 Hours 28 Minutes
77	OCC 213	POWERGRID	400KV-BALIPARA-MISA-2	POWERGRID	D	TESING OF LBB RELAY INSTALLED IN 400KV BNC-2 AND MISA-2 TIE BAY(408)	14/May/2024	10:00	14/May/2024	14:00	11/May/2024 10:42	13/May/2024 12:02	49 Hours 20 Minutes
78	OCC 213	POWERGRID	400KV-BISWANATH CHARIALI-BALIPARA-2	POWERGRID	D	TESING OF LBB RELAY INSTALLED IN 400KV BNC-2 AND MISA-2 TIE BAY(408)	14/May/2024	10:00	14/May/2024	14:00	11/May/2024 10:42	13/May/2024 12:02	49 Hours 20 Minutes
79	OCC 213	POWERGRID	132KV-RANGIA-MOTONGA-1	POWERGRID	D	For AMP Testing of bay equipment.	14/May/2024	07:00	14/May/2024	17:00	11/May/2024 10:42	13/May/2024 12:02	49 Hours 20 Minutes
80	OCC 213	AEGCL	132KV-GOHPUR-PAVOI-2	AEGCL	D	Corridor cleaning & jumper inspection	14/May/2024	09:00	14/May/2024	15:00	11/May/2024 11:25	13/May/2024 12:05	48 Hours 40 Minutes
81	OCC 213	AEGCL	220KV-AZARA-BOKO-1	AEGCL	D	CORRIDOR CLEANING	14/May/2024	09:00	14/May/2024	16:00	11/May/2024 11:25	13/May/2024 12:05	48 Hours 40 Minutes
82	OCC 213	AEGCL	132KV-SARUPATHAR-GOLAGHAT-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	14/May/2024	08:00	14/May/2024	16:00	11/May/2024 11:25	13/May/2024 12:05	48 Hours 40 Minutes
83	OCC 213	AEGCL	132KV-DHARMANAGAR (MISSION TILLA)-DULLAVCHERRA-1	AEGCL	TSE	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	14/May/2024	08:00	14/May/2024	16:00	11/May/2024 11:25	13/May/2024 12:05	48 Hours 40 Minutes
84	OCC 213	POWERGRID	TIE BAY ( ) OF 400KV-BISWANATH CHARIALI-BALIPARA-2 AND 400KV-BALIPARA-MISA-2 @BALIPARA - 400KV	POWERGRID	C	LBB RELAY REPLACEMENT WORKS	13/May/2024	09:00	14/May/2024	17:00	10/May/2024 10:08	12/May/2024 11:59	49 Hours 51 Minutes
85	OCC 213	POWERGRID	400KV-BALIPARA-BONGAIGAON-4	POWERGRID	D	AMP of Bay equipment	13/May/2024	09:00	13/May/2024	17:00	10/May/2024 10:08	12/May/2024 11:59	49 Hours 51 Minutes
86	OCC 213	AEGCL	132KV-GOHPUR-PAVOI-2	AEGCL	D	Corridor cleaning & jumper inspection	13/May/2024	09:00	13/May/2024	15:00	10/May/2024 11:26	12/May/2024 11:59	48 Hours 33 Minutes
87	OCC 213	AEGCL	220KV-AGIA-BTPS-2	AEGCL	D	CORRIDOR CLEANING	13/May/2024	09:00	13/May/2024	16:00	10/May/2024 11:26	12/May/2024 11:59	48 Hours 33 Minutes
88	OCC 213	AEGCL	220KV-SAMAGURI-SONAPUR-1	AEGCL	D	CORRIDOR CLEANING	13/May/2024	08:00	13/May/2024	16:00	10/May/2024 11:26	12/May/2024 11:59	48 Hours 33 Minutes
89	OCC 213	AEGCL	PANCHGRAM (NEW) - 132KV - BUS 2	AEGCL	D	PRE MONSOON MAINTENANCE	12/May/2024	06:30	12/May/2024	12:30	09/May/2024 10:11	11/May/2024 09:29	47 Hours 18 Minutes
90	OCC 213	POWERGRID	400KV-BALIPARA-BONGAIGAON-3	POWERGRID	D	AMP of Line Reactor.	11/May/2024	09:00	11/May/2024	17:00	08/May/2024 09:53	10/May/2024 09:53	47 Hours 53 Minutes
91	OCC 213	POWERGRID	132KV-TEZU-NAMSAI-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	11/May/2024	08:00	11/May/2024	17:00	08/May/2024 09:53	10/May/2024 09:53	47 Hours 53 Minutes
92	OCC 213	POWERGRID	400KV-BISWANATH CHARIALI-BALIPARA-4	POWERGRID	D	TESTING OF LBB RELAY INSTALLED IN 400KV BONGAIGAON-2 AND BNC-4 TIE BAY(417)	10/May/2024	10:00	10/May/2024	14:00	07/May/2024 08:36	09/May/2024 10:09	48 Hours 9 Minutes
 Saksham Rithe (Assistant Manager)													
 Chitrakshi Ghangrekar Dy. General Manager)													



93	OCC_213	POWERGRID	400KV-BALIPARA-BONGAIGAON-2	POWERGRID	D	TESTING OF LBB RELAY INSTALLED IN 400KV BONGAIGAON-2 AND BNC-4 TIE BAY(417)	10/May/2024	10:00	10/May/2024	14:00	07/May/2024 08:36	09/May/2024 10:09	48 Hours 9 Minutes
94	OCC_213	POWERGRID	132KV-TEZU-NAMSAI-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	10/May/2024	08:00	10/May/2024	17:00	07/May/2024 08:36	09/May/2024 10:09	48 Hours 9 Minutes
95	OCC_213	POWERGRID	132KV-AIZWAL-KUMARGHAT-1	POWERGRID	D	For Replacement of Vibration dampers along with infringement clearance in forest reserve area.	10/May/2024	08:00	10/May/2024	16:00	07/May/2024 08:36	09/May/2024 10:09	48 Hours 9 Minutes
96	OCC_213	AEGCL	132KV-GOHPUR-PAVOH-2	AEGCL	D	Corridor cleaning & jumper inspection	10/May/2024	09:00	10/May/2024	15:00	07/May/2024 10:26	09/May/2024 10:09	47 Hours 43 Minutes
97	OCC_213	MEPTCL	132KV-UMTRU-SARUSAJAI-1	MEPTCL	D	Changing of Disc insulator at Loc.100	10/May/2024	09:00	10/May/2024	16:00	07/May/2024 07:47	09/May/2024 10:09	48 Hours 9 Minutes
98	OCC_213	MEPTCL	132KV-UMTRU-SARUSAJAI-2	MEPTCL	D	Changing of Disc insulator at Loc.100	10/May/2024	09:00	10/May/2024	16:00	07/May/2024 07:47	09/May/2024 10:09	48 Hours 9 Minutes
99	OCC_213	Arunachal Pradesh	132KV-ALONG-DAPORJU-1	DOP,ARUNACHAL	C	Replacement of endangered GI members of tower no. DRJ-ALO 052 involving involving de-stringing of conductor , Dismantling of tower , replacement of GI member and re-stringing as mentioned in the attachment	10/May/2024	09:00	16/May/2024	18:00	07/May/2024 08:10	09/May/2024 10:09	48 Hours 9 Minutes
100	OCC_213	AEGCL	220KV-AGIA-AZARA-1	AEGCL	D	CORRIDOR CLEANING	10/May/2024	09:00	10/May/2024	16:00	07/May/2024 10:26	09/May/2024 10:09	47 Hours 43 Minutes
101	OCC_213	NAGALAND	132KV-SANIS-WOKHA-1	NAGALAND	D	Vegetation Clearance	10/May/2024	08:00	10/May/2024	15:00	07/May/2024 12:44	09/May/2024 10:09	45 Hours 25 Minutes
102	OCC_213	AEGCL	TINSUKIA - 132KV - BUS 1	AEGCL	D	PREVENTIVE MAINTENANCE.	10/May/2024	05:30	10/May/2024	08:30	07/May/2024 10:26	09/May/2024 10:09	47 Hours 43 Minutes
103	OCC_213	POWERGRID	TIE BAY (417) OF 400KV-BALIPARA-BONGAIGAON-2 AND 400KV-BISWANATH CHARIALI-BALIPARA-4 @BALIPARA - 400KV	POWERGRID	C	LBB RELAY REPLACEMENT WORKS	09/May/2024	09:00	10/May/2024	17:00	06/May/2024 11:22	08/May/2024 10:31	47 Hours 9 Minutes
104	OCC_213	POWERGRID	400KV/132KV IMPHAL(PG)-ICT-2	POWERGRID	C	For Implementation/Modification of Body Protection Scheme of Individual Single Phase Transformers	09/May/2024	07:00	10/May/2024	17:00	06/May/2024 11:22	08/May/2024 10:31	47 Hours 9 Minutes
105	OCC_213	POWERGRID	132KV-TEZU-NAMSAI-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	09/May/2024	08:00	09/May/2024	17:00	06/May/2024 11:22	08/May/2024 10:31	47 Hours 9 Minutes
 Saksham Rithe (Assistant Manager)						 Chitrakshi Ghangrekar Dy. General Manager)							

106	OCC 213	MEPTCL	132KV-KAHILIPARA-UMTRU-1	MEPTCL	AEGD	Changing of Disc insulator at Loc.21	09/May/2024	09:00	09/May/2024	16:00	06/May/2024 00:29	08/May/2024 10:31	48 Hours 31 Minutes
107	OCC 213	AEGCL	132KV-GOHPUR-PAVOD-1	AEGCL	D	Corridor cleaning & jumper inspection	09/May/2024	09:00	09/May/2024	15:00	06/May/2024 10:16	08/May/2024 10:31	48 Hours 15 Minutes
108	OCC 213	MEPTCL	132KV-KAHILIPARA-UMTRU-2	MEPTCL	AEGD	Changing of Disc insulator at Loc.21	09/May/2024	09:00	09/May/2024	16:00	06/May/2024 00:29	08/May/2024 10:31	48 Hours 31 Minutes
109	OCC 213	AEGCL	220KV-AGIA-BOKO-1	AEGCL	D	CORRIDOR CLEANING	09/May/2024	09:00	09/May/2024	16:00	06/May/2024 10:16	08/May/2024 10:31	48 Hours 15 Minutes
110	OCC 213	AEGCL	132KV-GOLAGHAT-MARIANI (AS)-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	09/May/2024	08:00	09/May/2024	16:00	06/May/2024 10:16	08/May/2024 10:31	48 Hours 15 Minutes
111	OCC 213	NAGALAND	132KV-SANIS-WOKHA-1	NAGALAND	D	Vegetation Clearance	09/May/2024	08:00	09/May/2024	15:00	06/May/2024 11:29	08/May/2024 10:31	47 Hours 2 Minutes
112	OCC 213	POWERGRID	220KV/132KV MOKOKCHUNG-ICT-1	POWERGRID	D	GD PROTECTION MODIFICATION AS PER CC IOM	08/May/2024	10:00	08/May/2024	15:00	05/May/2024 09:27	07/May/2024 11:52	49 Hours 52 Minutes
113	OCC 213	POWERGRID	132KV-TEZU-NAMSAI-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	08/May/2024	08:00	08/May/2024	17:00	05/May/2024 09:27	07/May/2024 11:52	49 Hours 52 Minutes
114	OCC 213	POWERGRID	400KV-SILCHAR- MISA-2 L/R@ MISA - 400KV	POWERGRID	D	Protection Modification of Line Reactor	08/May/2024	08:00	08/May/2024	16:00	05/May/2024 09:27	07/May/2024 11:52	49 Hours 52 Minutes
115	OCC 213	MEPTCL	220KV-BYRNHAT (KILLING)-MISA-1	MEPTCL	D	Checking of disc insulators,jumpers,connect ors,clamps etc.	08/May/2024	09:00	08/May/2024	16:00	05/May/2024 14:03	07/May/2024 11:52	45 Hours 49 Minutes
116	OCC 213	MEPTCL	220KV-BYRNHAT (KILLING)-MISA-2	MEPTCL	D	Checking of disc insulators,jumpers,connect ors,clamps etc.	08/May/2024	09:00	08/May/2024	16:00	05/May/2024 14:05	07/May/2024 11:52	45 Hours 47 Minutes
117	OCC 213	TSECL	132KV-MONARCHAK-UDAIPUR (BANDUAR)-1	TSECL	D	Routine Maintenance	08/May/2024	09:00	08/May/2024	16:00	05/May/2024 10:21	07/May/2024 11:52	49 Hours 31 Minutes
118	OCC 213	AEGCL	132KV-HAILAKANDI-PANCHGRAM (NEW)-1	AEGCL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	08/May/2024	08:00	08/May/2024	16:00	05/May/2024 10:55	07/May/2024 11:52	48 Hours 57 Minutes
119	OCC 213	NAGALAND	132KV-DOYANG-SANIS-1	NAGALAND	D	Vegetation Clearance	08/May/2024	08:00	08/May/2024	15:00	05/May/2024 10:11	07/May/2024 11:52	49 Hours 41 Minutes
120	OCC 213	AEGCL	132KV-TINSUKIA-MARGHERITA AS-1	AEGCL	D	REPAIRING OF DAMAGED TOWER AT LOCATION 54	08/May/2024	07:00	08/May/2024	16:00	05/May/2024 10:55	07/May/2024 11:52	48 Hours 57 Minutes
121	OCC 213	POWERGRID	220KV-BONGAIGAON-SALAKATI-2	POWERGRID	D	GD Trip modification	07/May/2024	10:00	07/May/2024	17:00	04/May/2024 11:20	06/May/2024 11:43	48 Hours 23 Minutes
122	OCC 213	POWERGRID	132KV-AIZWAL-MELRIAT-1	POWERGRID	D	"1. CRM testing of HYOSUNG make GIS CB installed in Aizawl bay at Melriat SS to be done. 2. Topping up of SF6 gas shall be done in 89A Isolator Chamber."	07/May/2024	09:00	07/May/2024	12:00	04/May/2024 11:20	06/May/2024 11:43	48 Hours 23 Minutes
<div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: center;">   Saksham Rithe (Assistant Manager) </div> <div style="text-align: center;">   Chitranshi Ghangrekar Dy. General Manager </div> </div>													

123	OCC_213	POWERGRID	132KV-TEZU-NAMSAI-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer Insulators at Power/Deep valley/River/SH/NH Crossing locations	07/May/2024	08:00	07/May/2024	17:00	04/May/2024 11:20	06/May/2024 11:43	48 Hours 23 Minutes
124	OCC_213	POWERGRID	132KV-AGTCCPP-KUMARGHAT-1	POWERGRID	D	Back stay arrangement to tower at loc no 289 of 132 KV KUMARGHAT- R C Nagar TL	07/May/2024	08:00	07/May/2024	17:00	04/May/2024 11:20	06/May/2024 11:43	48 Hours 23 Minutes
125	OCC_213	AEGL	132KV-GOHPUR-PAVOH-1	AEGL	D	Corridor cleaning & jumper inspection	07/May/2024	09:00	07/May/2024	15:00	04/May/2024 11:18	06/May/2024 11:43	48 Hours 25 Minutes
126	OCC_213	MEPTCL	132KV-AGIA-NANGALBIBRA-1	MEPTCL	D	Jungle clearance at T/Loc 240-248	07/May/2024	08:00	07/May/2024	15:00	04/May/2024 07:02	06/May/2024 11:43	49 Hours 43 Minutes
127	OCC_213	NAGALAND	132KV-DOYANG-SANIS-1	NAGALAND	D	Vegetation Clearance	07/May/2024	08:00	07/May/2024	15:00	04/May/2024 09:11	06/May/2024 11:43	49 Hours 43 Minutes
128	OCC_213	AEGL	132KV-TINSUKIA-MARGHERITA AS-1	AEGL	D	REPAIRING OF DAMAGED TOWER AT LOCATION 54	07/May/2024	07:00	07/May/2024	16:00	04/May/2024 11:18	06/May/2024 11:43	48 Hours 25 Minutes
129	OCC_213	POWERGRID	220KV/132KV MOKOKCHUNG-ICT-2	POWERGRID	D	GD PROTECTION MODIFICATION AS PER CC IOM	06/May/2024	10:00	06/May/2024	15:00	03/May/2024 08:51	05/May/2024 11:35	49 Hours 35 Minutes
130	OCC_213	POWERGRID	400 KV BONGAIGAON I & 400 KV BISWANATH CHARIALI III (414)AT BALIPARA	POWERGRID	C	LBB RELAY REPLACEMENT WORKS	06/May/2024	09:00	07/May/2024	17:00	03/May/2024 08:51	05/May/2024 11:35	49 Hours 35 Minutes
131	OCC_213	POWERGRID	220KV-BONGAIGAON-SALAKATI-1	POWERGRID	D	GD Trip modification	06/May/2024	10:00	06/May/2024	17:00	03/May/2024 08:51	05/May/2024 11:35	49 Hours 35 Minutes
132	OCC_213	POWERGRID	132KV-TEZU-NAMSAI-1	POWERGRID	D	For replacement of conventional porcelain Insulators by Composite Long rod Polymer insulators at Power/Deep valley/River/SH/NH Crossing locations	06/May/2024	08:00	06/May/2024	17:00	03/May/2024 08:51	05/May/2024 11:35	49 Hours 35 Minutes
133	OCC_213	AEGL	132KV-GOHPUR-PAVOH-1	AEGL	D	Corridor cleaning & jumper inspection	06/May/2024	09:00	06/May/2024	15:00	03/May/2024 10:52	05/May/2024 11:35	48 Hours 43 Minutes
134	OCC_213	AEGL	220KV-SONAPUR-SARUSAJAI-1	AEGL	D	CORRIDOR CLEANING	06/May/2024	08:00	06/May/2024	16:00	03/May/2024 10:52	05/May/2024 11:35	48 Hours 43 Minutes
135	OCC_213	AEGL	132KV-HAILAKANDI-DULLAVCHERRA-1	AEGL	D	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	06/May/2024	08:00	06/May/2024	16:00	03/May/2024 10:52	05/May/2024 11:35	48 Hours 43 Minutes
136	OCC_213	AEGL	132KV-TINSUKIA-MARGHERITA AS-1	AEGL	D	REPAIRING OF DAMAGED TOWER AT LOCATION 54	06/May/2024	07:00	06/May/2024	16:00	03/May/2024 10:52	05/May/2024 11:35	48 Hours 43 Minutes
137	OCC_213	TSECL	UDAIPUR (BANDUAR) - 132KV - BUS 1	TSECL	D	Routine Maintenance	05/May/2024	09:00	05/May/2024	16:00	02/May/2024 11:40	04/May/2024 12:01	48 Hours 21 Minutes
138	OCC_213	AEGL	132KV-RUPAI-MARGHERITA AS-1	AEGL	D	REPAIRING OF DAMAGED TOWER AT LOCATION 54	05/May/2024	07:00	05/May/2024	16:00	02/May/2024 11:40	04/May/2024 12:01	48 Hours 21 Minutes
139	OCC_213	POWERGRID	400KV-BINAGURI-BONGAIGAON-2	POWERGRID	D	For Defect rectification works	05/May/2024	08:00	05/May/2024	17:00	02/May/2024 08:10	04/May/2024 12:00	50 Hours 0 Minutes
140	OCC_213	POWERGRID	220KV-MARIANI (PG)-MOKOKCHUNG-1	POWERGRID	D	GD PROTECTION MODIFICATION AS PER CC IOM	04/May/2024	10:00	04/May/2024	15:00	01/May/2024 10:13	03/May/2024 11:33	49 Hours 20 Minutes
141	OCC_213	MIZORAM	KOLASIB - 132KV - BUS 1	P&ED,MIZO	D	Periodic Maintenance of Sub-Station with commissioning of 33kV CT for LV side of 12.5 MVA, 132/33kV Power Transformer - II and its corresponding differential relay at 132kV Bawktlang Sub Station.	04/May/2024	09:00	04/May/2024	16:00	01/May/2024 10:19	03/May/2024 11:33	49 Hours 14 Minutes
 Saksham Rithe (Assistant Manager)													 Chitrakshi Ghangrekar Dy. General Manager



142	OCC_213	AEGLCL	220KV-BALIPARA-SONABIL-2	AEGLCL,POVD		Corridor cleaning & Bay, Jumper tightening	04/May/2024	09:00	04/May/2024	15:00	01/May/2024 10:32	03/May/2024 11:33	49 Hours 1 Minutes
143	OCC_213	AEGLCL	132KV-JIRIBAM(PG)-PAILAPPOL-1	MSPCL,AEGLD		PREVENTIVE MAINTENANCE & CORRADOR CLEANING WORK	04/May/2024	09:00	04/May/2024	16:00	01/May/2024 10:32	03/May/2024 11:33	49 Hours 1 Minutes
144	OCC_213	Arunachal Pradesh	220 KV DEOMALI BAY AT AGBPP	NEEPCO	C	Deomali Bay at Kathalguri to be retrofitted with 220 Kv Hitachi Make Maintenance free Isolator	04/May/2024	08:00	05/May/2024	16:00	01/May/2024 10:08	03/May/2024 11:33	49 Hours 25 Minutes
145	OCC_213	AEGLCL	132KV-RUPAI-MARGHERITA AS-1	AEGLCL	D	REPAIRING OF DAMAGED TOWER AT LOCATION 54	04/May/2024	07:00	04/May/2024	16:00	01/May/2024 10:32	03/May/2024 11:33	49 Hours 1 Minutes
146	OCC_213	POWERGRID	TIE BAY ( ) OF 400KV/132KV SILCHAR-ICT-3 AND FUTURE @SILCHAR - 400KV	POWERGRID	D	AMP of Bay Equipment.	03/May/2024	09:00	03/May/2024	16:00	30/Apr/2024 10:52	02/May/2024 11:31	48 Hours 39 Minutes
147	OCC_213	AEGLCL	220KV-AGBPP-TINSUKIA-1	AEGLCL	D	PREVENTIVE MAINTENANCE & CORRADOR CLEANING WORK	03/May/2024	09:00	03/May/2024	16:00	30/Apr/2024 10:26	02/May/2024 11:31	49 Hours 5 Minutes
148	OCC_213	AEGLCL	132KV-SRIKONA-PAILAPPOL-1	AEGLCL	D	LINE MAINTENANCE & CORRADOR CLEANING WORK	03/May/2024	08:00	03/May/2024	16:00	30/Apr/2024 10:26	02/May/2024 11:31	49 Hours 5 Minutes
149	OCC_213	AEGLCL	AZARA - 400KV - BUS 2	AEGLCL	D	BUS TIGHTENING AND ISOLATOR ALIGNMENT WORK	03/May/2024	08:00	03/May/2024	16:00	30/Apr/2024 10:26	02/May/2024 11:31	49 Hours 5 Minutes
150	OCC_213	NAGALAND	132KV-MELURI-KIPHIRE-1	NAGALAND	D	Vegetation Clearance	03/May/2024	08:00	03/May/2024	15:00	30/Apr/2024 10:28	02/May/2024 11:31	49 Hours 3 Minutes
151	OCC_213	AEGLCL	132KV-RUPAI-MARGHERITA AS-1	AEGLCL	D	REPAIRING OF DAMAGED TOWER AT LOCATION 54	03/May/2024	07:00	03/May/2024	16:00	30/Apr/2024 10:26	02/May/2024 11:31	49 Hours 5 Minutes
152	OCC_213	POWERGRID	220KV-MARIANI (PG)-MOKOKCHUNG-2	POWERGRID	D	GD PROTECTION MODIFICATION	02/May/2024	10:00	02/May/2024	15:00	29/Apr/2024 08:55	01/May/2024 11:20	49 Hours 20 Minutes
153	OCC_213	POWERGRID	MARIANI (PG) - 220KV B/R 1	POWERGRID	D	1.Buchholz alarm signal to be incorporated in trip logic.	02/May/2024	09:00	02/May/2024	17:00	29/Apr/2024 08:55	01/May/2024 11:20	49 Hours 20 Minutes
154	OCC_213	POWERGRID	400KV-BISWANATH CHARIALI-BALIPARA-1 L/R@ BALIPARA - 400KV	POWERGRID	C	Replacement of Differential relay by Micom P643 Relay from Schneider make MICOM P633 relay	02/May/2024	09:00	03/May/2024	17:00	29/Apr/2024 08:55	01/May/2024 11:20	49 Hours 20 Minutes
155	OCC_213	POWERGRID	400KV-SILCHAR-MISA-1 L/R@ MISA - 400KV	POWERGRID	D	Gas Zone Trip modification of Elements & Line Bay equipments AMP	02/May/2024	08:00	02/May/2024	16:00	29/Apr/2024 08:55	01/May/2024 11:20	49 Hours 20 Minutes
156	OCC_213	POWERGRID	400KV-SILCHAR-MISA-1	INDIGRID	D	Gas Zone Trip modification of Elements & Line Bay equipments AMP	02/May/2024	08:00	02/May/2024	16:00	29/Apr/2024 08:55	01/May/2024 11:20	49 Hours 20 Minutes
157	OCC_213	MEPTCL	132KV-LUMSNONG-PANCHGRAM (NEW)-1	MEPTCL,AEGLD		Jungle Clearance at T/Loc 270 & 273	02/May/2024	10:00	02/May/2024	16:00	29/Apr/2024 07:46	01/May/2024 11:20	49 Hours 20 Minutes
158	OCC_213	AEGLCL	220KV-BALIPARA-SONABIL-1	AEGLCL,POVD		Corridor cleaning & Bay, Jumper tightening	02/May/2024	09:00	02/May/2024	15:00	29/Apr/2024 10:01	01/May/2024 11:20	49 Hours 19 Minutes
159	OCC_213	AEGLCL	132KV-LUMSNONG-PANCHGRAM (NEW)-1	MEPTCL,AEGLD		PREVENTIVE MAINTENANCE & CORRADOR CLEANING WORK	02/May/2024	08:00	02/May/2024	16:00	29/Apr/2024 10:01	01/May/2024 11:20	49 Hours 19 Minutes
160	OCC_213	NAGALAND	132KV-MELURI-KIPHIRE-1	NAGALAND	D	Vegetation Clearance	02/May/2024	08:00	02/May/2024	15:00	29/Apr/2024 11:38	01/May/2024 11:20	47 Hours 42 Minutes
<div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: center;">   Saksham Rithe (Assistant Manager) </div> <div style="text-align: center;">   Chitranshi Ghangrekar Dy. General Manager) </div> </div>													

161	OCC_213	POWERGRID	400KV/220KV MARIANI (PG)-ICT-2	POWERGRID	"1.PRIV NO/NC.LOGIC TO BE MODIFIED 2.OLTC OSR LOGIC MODIFICATION"	01/May/2024	09:00	01/May/2024	17:00	28/Apr/2024 11:01	30/Apr/2024 11:56	48 Hours 55 Minutes
162	OCC_213	POWERGRID	400KV-BISWANATH CHARIALI-SUBANSIRI-2 L/R@ BISWANATH CHARIALI - 400KV	POWERGRID	AMP of Line Reactor. Shutdown was approved in March 211th OCC. However same was not approved by NERLDC on D-3 due to system constraints. The shutdown was not rescheduled in April 212th OCC.	01/May/2024	09:00	01/May/2024	17:00	28/Apr/2024 11:01	30/Apr/2024 11:56	48 Hours 55 Minutes
163	OCC_213	NAGALAND	132KV-MELURI-KIPHIRE-1	NAGALAND	Vegetation Clearance	01/May/2024	08:00	01/May/2024	15:00	28/Apr/2024 10:37	30/Apr/2024 11:56	49 Hours 19 Minutes
<div style="display: flex; justify-content: space-between; align-items: center;"> <div style="text-align: center;">   Saksham Rithe (Assistant Manager) </div> <div style="text-align: center;">   Chitrankshi Ghangrekar Dy. General Manager) </div> </div>												