

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(भारत सरकार का उद्यम)

GRID CONTROLLER OF INDIA LIMITED

(A Govt. of India Enterprise)



उत्तर पूर्वी क्षेत्रीय भार प्रेषण केंद्र North Eastern Regional Load Despatch Centre
डाक रिज़ा, लापालांग, शिलांग – 793006 (मेघालय) ई-मेल: nerldco2@posoco.in
PO Rynjah, Lapalang, Shillong-793006 (Meghalaya) E-mail: nerldco2@posoco.in
Tel. : (0364) 2537470, 2537427 Fax : 2537486
CIN NO. U40105DL2009G01188682

सन्दर्भ : उपक्षेभाप्रेके/एस.ओ-II/126/7556

दिनांक/ Date : 27.03.2025

सेवा में/To,

बितरण सूची के अनुसार / As per Distribution List.

विषय/Sub: पूर्वोत्तर क्षेत्र की साप्ताहिक रिपोर्ट / WEEKLY REPORT OF NER.

महोदय / Sir,

यह सूचित किया जाता है पूर्वोत्तर क्षेत्र की दिनांक 17/03/25 से 23/03/25 अवधि का साप्ताहिक रिपोर्ट उत्तर पूर्वी क्षेत्रीय भार प्रेषण केंद्र की वेब साइट www.nerldc.in में उपलब्ध है।

This is to inform that Weekly Report w.e.f. 17/03/25 to 23/03/25 of North Eastern Region is available in NERLDC web site www.nerldc.in

धन्यवाद के साथ/ Thanking you.

संलग्नक / Encl. as above

भवदीय /Yours faithfully

(विश्वजीत साहू /Biswajit Sahu)
मुख्य महाप्रबंधक / Chief General Manager(SO)
उपक्षेभाप्रेके, गुवाहाटी/NERLDC, Guwahati

बितरण / Distribution :-

1. GENERAL MANAGER (TECH-1), TSECL, BANAMALIPUR, AGARTALA
2. CHIEF GENERAL MANAGER, AEGCL, KAHALIPARA SLDC, GUWAHATI
3. CHIEF ENGINEER (POWER), TRANSMISSION, PLANNING AND MONITORING, GOVT OF ARUNACHAL PRADESH, ITANAGAR
4. MD, MSPCL, KEISHAMPAT JUNCTION, IMPHAL WEST DIST. IMPHAL-795001
5. ENGINEER IN CHIEF (POWER), P&E DEPARTMENT, GOVT OF MIZORAM, AIZWAL
6. CHIEF ENGINEER (POWER), DEPARTMENT OF POWER, GOVT OF NAGALAND, KOHIMA
7. SUPERINTENDING ENGINEER (SLDC), MePTCL, 132 KV NEHU S/S COMPLEX, UMJARAIN, SHILLONG
8. MEMBER SECRETARY, NERPC, SHILLONG
9. CMD, Grid-India
10. CGM, NLDC, NEW DELHI
11. ED (WRLDC), MUMBAI
12. ED (NRLDC), NEW DELHI
13. ED (SRLDC), BANGALORE
14. ED (ERLDC), KOLKATA

उत्तर पूर्वी क्षेत्रीय भार प्रेषण केंद्र / North Eastern Regional Load Despatch Centre
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड / GRID CONTROLLER OF INDIA LIMITED
साप्ताहिक रिपोर्ट / WEEKLY REPORT

Year/वर्ष :	2025	Week No./सप्ताह संख्या:	12	Period/अवधि:	17-03-25	to/से	23-03-25
-------------	------	-------------------------	----	--------------	----------	-------	----------

(A) Frequency Profile/आवृत्ति प्रोफाइल:-

Date/दिनांक	Max(Hz)/अधिकतम(हर्ट्ज़)	Min(Hz)/न्यूनतम(हर्ट्ज़)	Average (Hz)/औसत(हर्ट्ज़)
17-03-2025	50.21	49.82	50.00
18-03-2025	50.23	49.74	50.01
19-03-2025	50.28	49.77	49.99
20-03-2025	50.19	49.64	49.98
21-03-2025	50.19	49.78	49.99
22-03-2025	50.29	49.63	50.00
23-03-2025	50.22	49.87	50.00

(B) Voltage Profile/वोल्टेज प्रोफाइल:-

Date	Azara- 400 kV		Balipara - 400kV		B. Chariali - 400kV		Bongaigaon - 400kV	
	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम
17-03-2025	409.00	402.00	407.00	394.00	405.00	391.00	411.00	399.00
18-03-2025	409.85	402.53	410.06	396.14	408.80	395.00	411.38	401.48
19-03-2025	409.85	402.17	410.72	396.53	408.33	395.00	411.66	398.18
20-03-2025	409.97	404.10	405.87	395.21	403.00	392.43	410.27	401.93
21-03-2025	411.00	403.00	412.00	395.00	409.00	394.00	411.00	401.00
22-03-2025	411.00	401.00	411.00	395.00	409.00	394.00	413.00	399.00
23-03-2025	409.00	401.00	407.00	392.00	405.00	391.00	412.00	399.00

Date	Byrnihat - 400kV		BgTPP - 400 kV		Imphal - 400kV		Kameng-400kV	
	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम
17-03-2025	410.00	397.00	411.00	400.00	411.00	396.00	408.00	395.00
18-03-2025	412.62	397.34	412.10	394.55	414.36	392.81	411.94	397.30
19-03-2025	411.95	398.19	412.15	400.87	414.16	394.75	411.94	396.30
20-03-2025	410.40	398.39	412.78	401.83	407.95	394.16	407.97	396.34
21-03-2025	413.00	400.00	413.00	401.00	413.00	397.00	412.00	394.00
22-03-2025	413.00	399.00	413.00	400.00	413.00	398.00	411.00	396.00
23-03-2025	410.00	396.00	412.00	400.00	407.00	393.00	408.00	394.00

Date	Misa - 400kV		Palatana - 400kV		RHEP - 400kV		Silchar- 400kV	
	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम
17-03-2025	406.00	393.00	405.00	399.00	409.00	397.00	412.00	398.00
18-03-2025	409.91	396.13	406.76	398.54	412.87	400.23	414.34	396.61
19-03-2025	409.91	396.13	406.30	398.78	412.72	398.12	412.35	398.20
20-03-2025	409.91	396.13	405.50	399.55	407.17	397.06	410.67	398.36
21-03-2025	408.00	395.00	407.00	400.00	413.00	398.00	414.00	400.00
22-03-2025	408.00	395.00	407.00	401.00	413.00	400.00	415.00	400.00
23-03-2025	406.00	393.00	405.00	400.00	410.00	394.00	410.00	397.00

Date	New Kohima - 400kV		Mariani(PG) - 400kV		PK Bari(ST) - 400kV		Surajmaninagar(ST)- 400kV	
	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम	Max/अधिकतम	Min/न्यूनतम
17-03-2025	411.00	396.00	413.00	398.00	403.00	396.00	402.00	395.00
18-03-2025	413.45	396.24	413.93	394.85	404.80	395.39	403.31	394.61
19-03-2025	414.61	394.46	410.87	396.72	404.57	395.54	402.99	394.52
20-03-2025	410.82	395.40	409.52	397.54	404.28	397.26	402.68	396.14
21-03-2025	413.00	396.00	411.00	397.00	405.00	397.00	403.00	396.00
22-03-2025	414.00	397.00	412.00	398.00	406.00	398.00	405.00	397.00
23-03-2025	411.00	394.00	410.00	395.00	404.00	397.00	403.00	396.00

C. Major Generation outages/प्रमुख उत्पादन कटौती :

Period/अवधि:	17-03-25	to/से	23-03-25				
Element/तत्व	Outage Date/कटौती दिनांक	Outage Time/कटौती समय	Outage Type/कटौती प्रकार	Reason/कारण	Revival Date/पुनरुद्धार दिनांक	Revival Time/पुनरुद्धार समय	
AGBPP - STG 1	17/Mar/2025	14:08	Fault Tripped	Low forward power tripped	17/Mar/2025	14:29	

D. Outage of Important Grid Elements due to Shutdown/शुटडाउन के कारण महत्वपूर्ण ग्रिड तत्वों का आउटेज :

Period/अवधि:	17-03-25	to/से	23-03-25			
Element/तत्व	Outage Date/कटौती दिनांक	Outage Time/कटौती समय	Shutdown/ Outage type/शुटडाउन/कटौती प्रकार	Reason/कारण	Revival Date/पुनरुद्धार दिनांक	Revival Time/पुनरुद्धार समय
132KV-BISWANATH CHARIALI-CHIMPU-1	18/Mar/2025	09:49	PLANNED	AMP of bay equipment	18/Mar/2025	15:49
132KV-HAILAKANDI-PANCHGRAM (NEW)-1	18/Mar/2025	09:27	PLANNED	ESTRINGING WORK IN BETWEEN LOC. NO. 70 & 77 OF THE 132 KV PANCHGRAM-HA	18/Mar/2025	16:12
132KV-AGARTALA (79 TILLA)-ROKHIA-2	18/Mar/2025	10:17	PLANNED	Pre-Monsoon Shutdown work 2025.	18/Mar/2025	17:03
220KV-TINSUKIA-NTPS-1	19/Mar/2025	10:28	PLANNED	CORRIDOR CLEARANCE	19/Mar/2025	16:41
132KV-DIMAPUR(PG)-IMPHAL-1	19/Mar/2025	09:39	POST OCC	work with safety precautions along section of Loc. 329-330 in view of very long span of the of abo	19/Mar/2025	17:21
220KV-JAWAHARNAGAR-SAMAGURI-1	19/Mar/2025	07:48	PLANNED	HEIGHT RISING OF CONDUCTOR SPAN BETWEEN LOC 224 AND LOC 236	19/Mar/2025	17:36
132KV-AMBASA-KAMALPUR-1	19/Mar/2025	09:26	PLANNED	Pre-Monsoon Shutdown work 2025.	19/Mar/2025	17:12
132KV-SARUPATHAR-BOKAJAN-1	19/Mar/2025	09:16	POST OCC	For corridor cleaning	19/Mar/2025	16:12
220KV-NTPS-Aimgong-1	19/Mar/2025	15:27	EMERGENCY	cutting of a tree branch which is at very close proximity and within the induction zone of the line	19/Mar/2025	16:55
132KV-HAILAKANDI-PANCHGRAM (NEW)-1	19/Mar/2025	08:17	PLANNED	ESTRINGING WORK IN BETWEEN LOC. NO. 70 & 77 OF THE 132 KV PANCHGRAM-HA	19/Mar/2025	15:04
400KV-BINAGURI-BONGAIGAON-1	19/Mar/2025	07:58	POST OCC	Replacement of damaged CLR caused due to lightning	19/Mar/2025	18:59
132KV-KARIMGANJ (AS)-KUMARGHAT-1	19/Mar/2025	10:15	POST OCC	nging work between location AP 11/0 and AP 11A/0 of 132kv Karimganj Baraimganj Railway Tract	19/Mar/2025	15:33
132KV-AGARTALA (79 TILLA)-BUDHJANGNAGAR-1	19/Mar/2025	10:13	PLANNED	Pre-Monsoon Shutdown work 2025.	19/Mar/2025	16:46
132KV-MONARCHAK-UDAIPUR (BANDUAR)-1	19/Mar/2025	09:42	PLANNED	Pre-Monsoon Shutdown work 2025.	19/Mar/2025	17:09
220KV-AGBPP-MARIANI (AS)-1	19/Mar/2025	10:58	EMERGENCY	Replacement of defective insulator string at Location no. 85	19/Mar/2025	15:20
132KV-BISWANATH CHARIALI-GOHIPUR-1	19/Mar/2025	09:44	PLANNED	AMP of bay equipment	19/Mar/2025	13:16
220KV-BTSP-RANGIA-2	20/Mar/2025	09:08	PLANNED	PREVENTIVE MAINTENANCE	20/Mar/2025	15:09
220KV-AGBPP-MARIANI (PG)	20/Mar/2025	15:07	PLANNED	For Primary injection and Stability Test of line with Main Bus -2	20/Mar/2025	16:40
132KV-AGARTALA (79 TILLA)-ROKHIA-2	20/Mar/2025	10:13	PLANNED	Pre-Monsoon Shutdown work 2025.	20/Mar/2025	17:39
400KV-BINAGURI-BONGAIGAON-1	20/Mar/2025	08:04	POST OCC	Replacement of damaged CLR caused due to lightning	20/Mar/2025	18:57
132KV-HAILAKANDI-PANCHGRAM (NEW)-1	20/Mar/2025	09:13	PLANNED	ESTRINGING WORK IN BETWEEN LOC. NO. 70 & 77 OF THE 132 KV PANCHGRAM-HA	20/Mar/2025	17:15
132KV-DIMAPUR(PG)-IMPHAL-1	20/Mar/2025	09:15	POST OCC	work with safety precautions along section of Loc. 329-330 in view of very long span of the of abo	20/Mar/2025	14:45
132KV-BODHJUNGUNAGAR-JIRANIA-1	20/Mar/2025	09:37	PLANNED	Pre-Monsoon Shutdown work 2025.	20/Mar/2025	17:02
132KV-JIRIBAM(PG)-PAILAPPOL-1	20/Mar/2025	10:07	PLANNED	CORRIDOR CLEANING & PREVENTIVE MAINTENANCE	20/Mar/2025	15:24
220KV-AGBPP-DEOMALI-1	20/Mar/2025	07:16	PLANNED	For Primary injection and Stability Test of ICT-1 with Main Bus -2	20/Mar/2025	13:43
220KV-JAWAHARNAGAR-SAMAGURI-1	20/Mar/2025	06:49	PLANNED	HEIGHT RISING OF CONDUCTOR SPAN BETWEEN LOC 224 AND LOC 236	20/Mar/2025	19:04
220KV-AGBPP-TINSUKIA-2	21/Mar/2025	09:49	PLANNED	CORRIDOR CLEARANCE	21/Mar/2025	18:19
132KV-HAILAKANDI-PANCHGRAM (NEW)-1	21/Mar/2025	09:18	PLANNED	PREVENTIVE MAINTENANCE & CORRIDOR CLEANING WORK	23/Mar/2025	17:25
132KV-DIMAPUR(PG)-IMPHAL-1	21/Mar/2025	09:02	POST OCC	work with safety precautions along section of Loc. 329-330 in view of very long span of the of abo	21/Mar/2025	16:29
220KV-MISA-KOPILLI-1	21/Mar/2025	07:18	POST OCC	For Rectification of OPGW span (Loc-108 to L11) snapped during lightning.	21/Mar/2025	14:27
220KV-AGIA-BTSP-2	21/Mar/2025	09:36	PLANNED	CORRIDOR CLEANING	21/Mar/2025	15:51
220KV-MISA-KOPILLI-2	21/Mar/2025	07:19	POST OCC	For Rectification of OPGW span (Loc-108 to L11) snapped during lightning.	21/Mar/2025	14:29
220KV-JAWAHARNAGAR-SAMAGURI-1	21/Mar/2025	07:02	PLANNED	HEIGHT RISING OF CONDUCTOR SPAN BETWEEN LOC 224 AND LOC 236	21/Mar/2025	17:37
400KV-BINAGURI-BONGAIGAON-2	21/Mar/2025	08:14	POST OCC	Replacement of damaged CLR caused due to lightning	21/Mar/2025	18:46
132KV-AGARTALA (79 TILLA)-BUDHJANGNAGAR-1	21/Mar/2025	10:09	PLANNED	Pre-Monsoon Shutdown work 2025.	21/Mar/2025	16:49
220KV-AGBPP-TINSUKIA-1	21/Mar/2025	07:09	POST OCC	For Primary injection and Stability Test of line with Main Bus -2	21/Mar/2025	09:36
132KV-BARAMURA-JIRANIA-1	22/Mar/2025	09:15	PLANNED	Pre-Monsoon Shutdown work 2025.	23/Mar/2025	17:20
132KV-DIMAPUR(PG)-IMPHAL-1	22/Mar/2025	08:52	POST OCC	work with safety precautions along section of Loc. 329-330 in view of very long span of the of abo	23/Mar/2025	18:49
400KV-BINAGURI-BONGAIGAON-2	22/Mar/2025	08:05	POST OCC	Replacement of damaged CLR caused due to lightning	22/Mar/2025	18:49
220KV-JAWAHARNAGAR-SAMAGURI-1	22/Mar/2025	07:08	PLANNED	HEIGHT RISING OF CONDUCTOR SPAN BETWEEN LOC 224 AND LOC 236	22/Mar/2025	16:50
132KV-KUMARGHAT-P.K BAR-1	23/Mar/2025	09:42	PLANNED	Pre-Monsoon Shutdown work 2025.	23/Mar/2025	17:11
400KV-BINAGURI-BONGAIGAON-2	23/Mar/2025	09:36	POST OCC	Replacement of damaged CLR caused due to lightning	23/Mar/2025	19:04
220KV-AGBPP-MARIANI (AS)-1	23/Mar/2025	10:48	POST OCC	r new BB relay stability testing works/For Primary injection and Stability Test of line with Main Bus	23/Mar/2025	12:08
132KV-TEZLU-NAMSAL-1	23/Mar/2025	08:49	PLANNED	and Jumpering upto Main & Transfer Bus of new bays. S/D is required to facilitate augmentation of	23/Mar/2025	18:31
220KV-JAWAHARNAGAR-SAMAGURI-1	23/Mar/2025	06:48	PLANNED	HEIGHT RISING OF CONDUCTOR SPAN BETWEEN LOC 224 AND LOC 236	23/Mar/2025	16:50
132KV-KHANDONG-KHLEHRIAT-1	23/Mar/2025	18:59	EMERGENCY	Voltage Discrepancy in Line CVT	23/Mar/2025	20:24

E. Outage of Important Grid Elements due to System Repts & Tripping/सिस्टम अनुरोधों और ट्रिपिंग के कारण महत्वपूर्ण ग्रिड तत्वों का आउटेज :

Element/तत्व	Outage Date/कटौती दिनांक	Outage Time/कटौती समय	Period/अवधि: Shutdown Outage type/बंदवहन कटौती प्रकार	Reason/कारण	17-03-25	to/तक	23-03-25	Revival Date/पुनरुद्धार दिनांक	Revival Time/पुनरुद्धार समय	End 1-Relay Indication & Reason/अंत 1-रिले संकेत एवं कारण	End 2-Relay Indication & Reason/अंत 2-रिले संकेत एवं कारण
132KV-DIMAPUR(PG)-KOHIMA-1	17/Mar/2025	17:22	Fault Tripped	Tripped on DP	17/Mar/2025	17:40		17/Mar/2025	17:40	B-ph, Z-1, 1.16KA, 36.216 kms	Z-1, B-Ph
132KV-BARAMURA-JIRANIA-1	17/Mar/2025	20:40	Fault Tripped	Tripped on DP	19/Mar/2025	06:45		19/Mar/2025	06:45	Details awaited	DP, ZIL B-ph, 16.65 km
132KV-KHANDONG-KOPLI-1	17/Mar/2025	13:53	Fault Tripped	Differential protection operated, Z-1, RYB phase	17/Mar/2025	16:12		17/Mar/2025	16:12	Differential protection operated, Z-1, RYB phase	No Tripping
132KV-UMTRU-SARUSAJAI-1	17/Mar/2025	12:56	Fault Tripped	Tripped on DP	17/Mar/2025	14:55		17/Mar/2025	14:55	Z1, RYB ph, OC, 3.901km	details awaited
220KV-JAWAHARNAGAR-SAMAGRI-1	17/Mar/2025	06:46	Fault Tripped	Tripped on DP	18/Mar/2025	16:24		18/Mar/2025	16:24	Z1, B-PH, 46.8 Km, 2.74 kA	Z1, B-PH, 49.7 Km
132KV-RODNG-TIZU-1	18/Mar/2025	15:56	Fault Tripped	Tripped on DP	18/Mar/2025	21:14		18/Mar/2025	21:14	AFAS B-N, 0.904amp -47.961 KMs	No Tripping
132KV-KAHILIPARA-UMTRU-2	19/Mar/2025	08:50	Fault Tripped	No indication found at Umtru end (Line was silc charred from Umtru end)	19/Mar/2025	09:29		19/Mar/2025	09:29	No indication found at Umtru end (Line was silc charred from Umtru end)	Details awaited
132KV-PK BARI-PK BARI (STERLITE)-1	19/Mar/2025	15:34	Fault Tripped	Tripped on DP	19/Mar/2025	17:54		19/Mar/2025	17:54	Details awaited	Details awaited
132KV-DAPORLU-BASAR-1	19/Mar/2025	08:44	Fault Tripped	Tripped on DP	19/Mar/2025	12:13		19/Mar/2025	12:13	No Tripping	DP, Z1, R-Y, 33.15 km
132KV-BADARPUR-KOLASIB-1	20/Mar/2025	14:24	Fault Tripped	Tripped on DP	20/Mar/2025	15:38		20/Mar/2025	15:38	Details awaited	Details awaited
132KV-AIZWAL-KOLASIB-1	20/Mar/2025	14:24	Fault Tripped	Tripped on DP	20/Mar/2025	15:26		20/Mar/2025	15:26	Details awaited	Details awaited
132KV-ALONG-PASIGHAT-1	21/Mar/2025	18:01	Fault Tripped	Jumper Broken - B phase	23/Mar/2025	13:27		23/Mar/2025	13:27	No tripping	No indication
132KV-AGARTALA (99 TELA)-ROKHA-2	22/Mar/2025	22:41	Fault Tripped	Tripped on DP	23/Mar/2025	12:20		23/Mar/2025	12:20	B-ph, 2.437 kA, Z1, E-C22.6 KM	O/C, R-ph, >=1.512 kA, E-F-A648 KM
132KV-PAREJTANAGAR-1	23/Mar/2025	17:18	Fault Tripped	Tripped on DP	23/Mar/2025	17:56		23/Mar/2025	17:56	Z1, Distance Protection, 11.41km	No tripping
132KV-TENGA-KHUPH-1	23/Mar/2025	18:18	Fault Tripped	Tripped on DP	23/Mar/2025	19:41		23/Mar/2025	19:41	Details awaited	Details awaited

F. Major Grid Disturbance/प्रमुख ग्रिड विघ्न:

		Period/अवधि:	17-03-25	to	23-03-25	
SI No./क्रम संख्या	Occurrence/घटना		Normalization/सामान्यीकरण		Disturbance Type/गड़बड़ी प्रकार	Areas Affected/प्रभावित क्षेत्र
	Date/दिनांक	Time/समय	Date/दिनांक	Time/समय		
1	18-03-2025	15:56:00	18-03-2025	21:14:00	GD I	Tezu and Namsai areas of Arunachal Pradesh Power System.
2	20-03-2025	14:24:00	20-03-2025	15:26:00	GD I	Kolasib, Bairabi and Tural area of Mizoram Power System.
3	23-03-2025	18:18:00	23-03-2025	19:41:00	GD I	Khupi & Seppa area of Arunachal Pradesh Power System
4	23-03-2025	12:09:00	23-03-2025	12:32:00	GD I	Mawlyndeep S/S of Meghalaya Power System

		Period/अवधि:	17-03-25	to/से	23-03-25	
SI No./क्रम संख्या	Name of the Elements/तत्वों का नाम	Approved From Date and Time/स्वीकृत द्वारा दिनांक और समय	Approved To Date and Time / स्वीकृत से दिनांक और समय	Actual S/D availed/वास्तविक शटडाउन लिया	Actual S/D return/वास्तविक शटडाउन वापस	Reason / Remarks/कारण/टिप्पणी
----- NIL -----						

H. Non-compliance of instructions of SLDC by SEB/distribution licenses /bulk consumers/एस.ई.बी./वितरण लाइसेंस/थोक उपभोक्ताओं द्वारा एस.एल.डी.सी. निर्देशों का अनुपालन न करना

This is to inform that Weekly Report w.e.f. 30/12/24 to						
		Period/अवधि:	17-03-25	to/से	23-03-25	
Date/दिनांक	Time/समय	Agency/एजेंसी		Details of Non-compliance/गैर-अनुपालन का विवरण		
----- NIL -----						